

# SIKKIM

## GOVERNMENT



## GAZETTE

**EXTRAORDINARY  
PUBLISHED BY AUTHORITY**

**Gangtok**

**Thursday 27th June, 2013**

**No. 321**

**SIKKIM STATE ELECTRICITY REGULATORY COMMISSION (SSERC)  
GANGTOK - 737102**

**No: 08/SSERC/GC/2013**

**Dated the 19<sup>th</sup> February, 2013**

### **NOTIFICATION STATE GRID CODE REGULATIONS**

In exercise of the powers conferred under clause (h) of sub-section (1) of section 86 of Electricity Act, 2003 (36 of 2003) and all other powers enabling it in this behalf, the Sikkim State Electricity Regulatory Commission hereby makes the following Regulations:

#### **CHAPTER - 1: GENERAL**

##### **1.1 Short title, extent and commencement**

- 1) These regulations may be called the Sikkim State Electricity Regulatory Commission (State Grid Code) Regulations, 2013
- 2) These regulations shall extend to the whole State of Sikkim
- 3) These regulations shall come into force from the date of publication in the Sikkim State official gazette.

##### **1.2 Scope**

The State Grid Code regulations shall apply to all Intra-State Transmission System participants, including;

- a) State Transmission Utility and Transmission Licensees,
- b) Generating Stations connected to Intra-State Transmission System,
- c) Distribution Licensees connected with Intra-State Transmission System,
- d) EHV Consumers of Distribution Licensee directly connected to Intra-State Transmission System,
- e) Open access customers availing open access on Intra-State Transmission system,
- f) Captive Generators connected to Intra-State Transmission System.

### 1.3 Definitions

1) In these regulations, the following words and expressions shall, unless the subject matter or context otherwise requires or is inconsistent therewith, bear the following meanings:

|      |                                    |   |
|------|------------------------------------|---|
| (1)  | Act                                | The Electricity Act, 2003 (Act No. 36 of 2003) as amended from time to time   |
| (2)  | Accredited Testing Laboratory      | A testing laboratory accredited by National Accreditation Board for Testing and Calibration Laboratories (NABL);  |
| (3)  | Active Power                       | The product of voltage and the in-phase component of alternating current measured in units of watts and standard multiples thereof,   |
| (4)  | Apparatus                          | All the electrical apparatus like machines, fittings, accessories and appliances in which electrical conductors are used.   |
| (5)  | Apparent                           | The product of voltage and alternating current measured in unit of volt-amperes Power and standard multiples thereof,   |
| (6)  | Appropriate Transmission Utility   | The "Central Transmission Utility" (CTU) or the "State Transmission Utility" (STU), as the case may be  |
| (7)  | Area of Supply electricity.        | Area within which a Distribution Licensee is authorized by his license to supply  |
| (8)  | Authority of the Act.              | Central Electricity Authority (CEA) referred to in sub-section (1) of Section 70  |
| (9)  | Automatic Voltage Regulator (AVR)  | A continuously acting automatic excitation control system to control the voltage of a Generating Unit measured at the generator terminals.  |
| (10) | Availability Based Tariff (ABT)    | A tariff structure based on availability of generating units and having components, viz, Capacity Charges (CC), Energy Charges (EC) or Charges (VC) and charges for Unscheduled Interchange (UI)  |
| (11) | Beneficiary                        | A person who has share in State Generating Stations (SGS)/ Inter-State Generating Stations (ISGS) or bilateral exchanges including open access users;   |
| (12) | Bulk Consumer                      | A Consumer who avails supply at voltage of 33 kV or above.  |
| (13) | Buyer                              | Any generating company or licensee or consumer whose system receives electricity from another generating company or licensee.   |
| (14) | Captive Power Plant (CPP)          | A Power Plant set up by any person to generate electricity for his own use and includes a power plant set up by any co-operative society or association of persons for generating electricity primarily for use of members of such co-operative society or association. |
| (15) | Central Commission                 | Central Electricity Regulatory Commission (CERC) referred to in sub-Section (1) of section 76 of the Act  |
| (16) | Central Transmission Utility (CTU) | Any Government Company which the Central Government may notify under sub section (1) of Section 38 of the Act.  |

|      |                     |  |
|------|---------------------|--|
| (17) | Check Meter         | A meter, which shall be connected to the same core of the Current Transformer (CT) and Voltage Transformer (VT) to which main meter is connected and shall be used for accounting and billing of electricity in case of failure of main meter.   |
| (18) | Commission          | Sikkim State Electricity Regulatory Commission (SSERC)   |
| (19) | Connectivity        | For a generating station, including a captive generating plant, a bulk consumer or an intra-state transmission licensee means the state of getting connected to the intra-state transmission system.   |
| (20) | Connection          | A point at which a Plant and / or Apparatus connects to the Transmission / point Distribution System.  |
| (21) | Constituent         | A Distribution Licensee or Deemed Distribution Licensee of the State, a Generating Company having an SGS, State Transmission Utility, State Transmission Licensees, Open access customers.   |
| (22) | Consumer            | Any person who is supplied with electricity for his own use by a licensee or the Government or by any other person engaged in the business of supplying electricity to public under the Act or any other law for the time being in force and includes any person whose premises are for the time being connected for the purpose of receiving electricity with the works of a licensee, the Government or such other person, as the case may be. |
| (23) | Control Area        | A control area is an electrical system bounded by interconnections (tie lines) metering and telemetry which controls its generation and / or load to maintain its interchange schedule with other control areas whenever required to do so and contributes to frequency regulation of the synchronously operating system.  |
| (24) | Demand              | The demand of Active Power in MW and Reactive Power in MVAR of electricity unless otherwise stated.  |
| (25) | Demand control      | Any of the following methods of achieving a load reduction:<br>(a) Consumer Load Management initiated by Users.<br>(b) Consumer Load reduction by disconnection initiated by Users (other than following an instruction from Load Despatch Centre).<br>(c) Consumer Load reduction instructed by the Load Despatch Centre<br>(d) Automatic Under Frequency Load Disconnection (e) Emergency manual Load Disconnection                            |
| (26) | Despatch Schedule   | The ex-power plant net MW and MWh output of a generating station, schedules to be exported to the Grid from time to time.  |
| (27) | Drawal Schedule     | The summation of the station-wise ex-power plant drawal schedules from all ISGS / SGS and drawal from regional grid consequent to other long term access, medium term and short term open access transactions.   |
| (28) | df/dt Relay         | A relay which operates when the rate of change of system frequency (over time) goes higher than a specified limit and initiates load shedding  |
| (29) | Distribution system | The system of wires and associated facilities between the delivery points on the transmission lines or the generating station connection and the point of connection to the installation of the consumers.   |

|      |                                    |   |
|------|------------------------------------|---|
| (30) | Drawal                             | The import / export of electrical energy from / to the grid   |
| (31) | Energy Accounting and Audit Meters | Meters used for accounting of the electricity to various segments of electrical system so as to carry out further analysis to determine the consumption and loss of energy therein over a specified time period;  |
| (32) | Entitlement                        | Share of a beneficiary (in MW / MWh) in the installed capacity/output of an ISGS / SGS.   |
| (33) | Event                              | An unscheduled or unplanned occurrence in the State Transmission System including faults, incidents and breakdowns.   |
| (34) | Extra High Voltage (EHV)           | Voltage exceeding 33000 volts under normal conditions subject to the percentage variation allowed by the Authority  |
| (35) | Forced Outage                      | An Outage of State Generating Station or any of Power Station equipment, generally due to sudden failure of one or more parts of equipment at a generating station, of which no notice can be given by the Generator to STU and also include outage of transmission line and any substation equipment of which no notice can be given by State Transmission Utility.  |
| (36) | Generating Company                 | Any company or body corporate or association or body of individuals, whether incorporated or not, or artificial juridical person, which owns or operates or maintains a generating station.   |
| (37) | Generating Station                 | Any station for generating electricity, including any building and plant with step-up transformer, switchyard, switch gear, cables or other appurtenant equipment, if any, used for that purpose and the site thereof, a site intended to be used for a generating station, and any building used for housing the operating staff of a generating station and where electricity is generated by water-power, includes penstocks, head and tail works, main and regulatory reservoirs, dams and other hydraulic works, but does not in any case include any sub station. |
| (38) | Grid                               | High Voltage back bone system of inter-connected Transmission Lines, Sub Stations and Generating plants.  |
| (39) | Grid Standards                     | Grid Standards specified by the Central Electricity Authority under Clause (d) of section 73 of the Act.  |
| (40) | High Voltage or HV                 | Voltage greater than 400 volts and does not exceed 33000 volts under normal conditions subject to the percentage variation allowed by the Authority.  |
| (41) | Independent Power Producer (IPP)   | A generating company not owned / controlled by the Central/State government.  |
| (42) | Indian Electricity (IEGC)          | Regulation describing the philosophy and the responsibilities for planning and operation of Indian power system specified by the Commission in accordance Grid Code with sub section 1(h) of Section 79 of the Act.   |
| (43) | Indian Standards                   | Those Standards and Specifications approved by the Bureau of Indian Standards.  |

|      |                                       |  |
|------|---------------------------------------|--|
| (44) | Instrument Transformer                | The Current Transformer (CT), Voltage Transformer (VT) and Capacitor Voltage Transformer (CVT)   |
| (45) | Interconnecting Transformer           | Transformer connecting EHV lines of different voltage systems.   |
| (46) | Interface Meter                       | A meter used for accounting and billing of electricity, connected at the point of interconnection between electrical systems of generating company, licensee and consumers, directly connected to the Inter-State Transmission System or Intra -State Transmission system who have to be covered under ABT and have been permitted open access by the Appropriate Commission.  |
| (47) | Inter-State Generating Station (ISGS) | A Central generating station or other generating station in which two or more States have shares.  |
| (48) | Inter-State Transmission System       | Inter-State Transmission System includes:<br>(i) Any system for the conveyance of electricity by means of a main transmission line from the territory of one State to another State;<br>(ii) The conveyance of electricity across the territory of an intervening State as well as conveyance within a State, which is incidental to such inter-state transmission of electricity.<br>(iii) The transmission of electricity within the territory of a State built, owned, and operated maintained or controlled by the Central Transmission Utility. |
| (49) | Isolation                             | The disconnection of EHV / HV Apparatus from the remainder of the System in which that EHV / HV Apparatus is situated.   |
| (50) | Lean Period                           | That period in a day when the electrical power demand is lowest  |
| (51) | License                               | A license granted under section 14 of the Act.   |
| (52) | Licensee                              | A person who has been granted a license under section 14 of the Act.   |
| (53) | Load                                  | The MW/MWh consumed by a utility / installation  |
| (54) | Low Voltage or LV                     | Voltage not exceeding 440 volts  |
| (55) | Main Meter                            | A meter which would primarily be used for accounting and billing of electricity  |
| (56) | Main protection                       | Protection equipment or system expected to have priority in initiating either a fault clearance or an action to terminate an abnormal condition in a power system.   |
| (57) | Open Access                           | The non-discriminatory provision for the use of transmission lines or distribution system or associated facilities with such lines or system by any licensee or consumer or a person engaged in generation in accordance with the regulations specified by the Appropriate Commission.   |
| (58) | Operation                             | A scheduled or planned action relating to the operation of a system.   |
| (59) | Operational procedure                 | Management instructions and procedures, both for the safety rules and for the local and remote operation of plant and apparatus, issued in connection with the actual operation of plant and/or apparatus at or from a connecting site.  |
| (60) | Outage                                | A total or partial regulation in availability due to repair and maintenance of the Transmission or Distribution or Generation facility or defect in Auxiliary System.  |

|      |                                      |   |
|------|--------------------------------------|---|
| (61) | Part Load                            | The condition of a generating station, which is loaded but is not running at its declared availability.   |
| (62) | Partial shutdown                     | A shutdown of a part of the system resulting in failure of power supply, either from external connections or from the healthy part of the system.   |
| (63) | Peak period                          | That period in a day when the electrical power demand is highest.   |
| (64) | Person                               | Any company or body corporate or association or body of individuals, whether incorporated or not, or artificial juridical person.   |
| (65) | Planned outage                       | An outage of generating plant or part of the Transmission system, or part of a User's System co-ordinated by SLDC.  |
| (66) | Power factor                         | The ratio of Active Power (KW) to Apparent Power (KVA)  |
| (67) | Power System                         | Power system means all aspects of generation, transmission, distribution and supply of electricity and includes one or more of the following namely:<br>a) Generating Station<br>b) Transmission or main transmission lines<br>c) Sub-stations<br>d) Tie-lines)<br>e) Load dispatch activities<br>f) Mains or distribution mains<br>g) Electric supply lines<br>h) Overhead lines<br>i) Service lines<br>j) Works |
| (68) | Protection                           | The scheme and apparatus for detecting abnormal conditions on a system and initiating fault clearance or actuating signals or indications.  |
| (69) | Rated MW                             | The "Name plate" MW output of a Generating machine, being that output up to which the Generating machine is designed to operate.  |
| (70) | Reactive Power                       | The product of voltage and current and the sine of the phase angle between them measured in units of volt-amperes reactive and standard multiples thereof;  |
| (71) | Requester                            | A person such as Generating Company including captive generating plant or Transmission Licensee (excluding State Transmission Utility) or Distribution Licensee or Bulk Consumer, who is seeking connection of his new or expanded electrical plant in the Grid at Voltage level exceeding 33 kV.   |
| (72) | Regional Load Despatch Centre (RLDC) | 'Regional' Load Despatch Centre' means the Centre established under section (1) of sub-Section 27 of the Act.   |
| (73) | Safety Rules                         | The rules framed by the Users and the transmission licensee to ensure safety to persons working on plant / apparatus.   |
| (74) | Start - Up                           | The action of bringing a generating unit from shutdown to synchronous speed.  |
| (75) | State Grid Code                      | Electricity Grid Code for the State of Sikkim, a document describing the procedures and the responsibilities for planning and operation of the Grid of Sikkim State specified by the State Commission (SSERC).  |



|      |   |  |
|------|---|--|
| (76) | State Load Despatch Centre (SLDC)                   | 'State Load Despatch Centre' means the Centre established under sub-section (1) of Section 31 of the Act.  |
| (77) | State Transmission System                           | Any system for transmission of electricity other than an Inter-State Transmission System and includes.<br>i) Any system for the conveyance of electricity by means of a main transmission line within the territory of the State.<br>ii) The transmission of electricity within the territory of State on a system built, owned, operated, maintained or controlled by STU.  |
| (78) | State Transmission Utility (STU)                    | The Government Company specified as such by the State Government under sub-section (1) of section 39 of the Act.   |
| (79) | Sub-station   | Station for transforming or converting electricity for the transmission or distribution thereof and includes transformers, converters, switchgears, capacitors, synchronous condensers, structures, cables and other appurtenant equipment and any buildings used for that purpose and the site thereof.   |
| (80) | Supervisory Control and Data Acquisition or (SCADA) | The communication links and data processing systems, which provide information to enable implementation of requisite supervisory and control actions.  |
| (81) | Supplier  | Any generating company or licensee from whose system electricity flows into the system of another generating company or licensee or consumer   |
| (82) | Synchronized  | Those conditions where an incoming generating unit or system is connected to the bus bars of another system so that the frequencies and phase relationships of that generating unit or system as the case may be, and the system to which it is connected are identical.   |
| (83) | Time Block  | Block of 15 minutes each for which Special Energy Meters record specified electrical parameters and quantities with first time block starting at 00.00 Hrs   |
| (84) | Transmission License                                | A License granted under Section 14 of the Act to transmit electricity.   |
| (85) | Transmission licensee                               | A licensee authorized to establish and operate transmission lines  |
| (86) | Transmission lines                                  | All high pressure cables and overhead lines (not being an essential part of the distribution system of a licensee) transmitting electricity from a generating station to another generating station or a sub station, together with any step-up and step-down transformers, switch-gear and other works necessary to and used for the control of such cables or overhead lines, and such buildings or part thereof as may be required to accommodate such transformers, switch-gear and other works. |
| (87) | Transmission system                                 | The system consisting of high pressure cables and overhead lines of transmission licensee including electrical sub-stations, for transmission of electrical power from the generating station upto connection point / interface point with the distribution system. This shall not include any part of the distribution system.  |

|      |                              |   |
|------|------------------------------|---|
| (88) | Under Frequency Relay        | An electrical measuring relay intended to operate when its characteristic quantity reaches the relay settings by decrease in frequency.   |
| (89) | Unscheduled Interchange (UI) | In a time block for a generating station or a seller means its total actual generation minus its total scheduled generation and for a beneficiary or buyer means its actual drawal minus its total scheduled drawal.  |
| (90) | User                         | A person such as a Generating Company including Captive Generating Plant or Transmission Licensee (other than State Transmission Utility) or Distribution Licensee or Bulk Consumer, whose electrical plant is connected to the State Transmission System at a voltage level 33 kV and above. |

- 2) Words and expressions used in this State Grid Code regulations and not defined here in but defined in the Act shall have the meaning assigned to them in the Act.

#### **1.4 Objectives of State Grid Code**

1.4.1 The State Grid Code Regulations lay down the rules, guidelines and standards to be followed by all Users of the State Transmission System, to plan, develop, operate and maintain an efficient and coordinated power system in the State of Sikkim in coordination with the Eastern Regional Grid as per the provisions of Indian Electricity Grid Code (IEGC) issued by Central Electricity Regulatory Commission (CERC) as amended from time to time and also in line with the National Electricity Policy.

1.4.2 The principal objectives of the State Grid Code are:

- (a) To provide clarity in the functions of the STU, State Generation Companies, Transmission and Distribution Licensees, IPPs / CPPs and open access customers connected to the State Grid by specifying their respective roles, responsibilities and obligations with respect to the operation of the State Grid.
- (b) To improve the Grid stability and achieve the standards of system performance.
- (c) To specify the transmission connectivity requirement for new entrants i.e., future new generating companies, distribution/trading licensees, open access customers and consumers.
- (d) To document the normal practices in grid operation for easy reference and for compliance.
- (e) To elicit with generators on the performance characteristics of their plant to meet the connectivity requirements.
- (f) To provide a mechanism for clear and consistent disclosure of all information between the utilities concerned.
- (g) To indicate how generation is to be scheduled and dispatched.
- (h) To actually enforce what is verbally agreed.

#### **1.5 Compatibility with Indian Electricity Grid Code (IEGC)**

The State Grid Code Regulations shall be consistent/compatible with the IEGC. However, in matters relating to inter-State transmission, if any provisions of the State Grid Code are inconsistent with the provisions of the IEGC, then the provisions of IEGC as approved by CERC shall prevail.



## CHAPTER - 2: ROLE OF VARIOUS ORGANIZATIONS

### 2.1 Energy and Power Department of Sikkim (EPDS)

The EPDS is responsible for generation, transmission and distribution of electricity in the State of Sikkim. EPDS is a deemed licensee under the provisions of Electricity Act, 2003 in the State of Sikkim.

### 2.2 State Transmission Utility

The State Government of Sikkim shall notify the transmission wing of EPDS in terms of Section 39 of the Electricity Act, 2003, to act as **State Transmission Utility (STU)**, till such time a separate transmission corporation is established. STU shall not engage in the business of trading in electricity.

The State Transmission Utility shall discharge the functions as stipulated under the Electricity Act, 2003. Section 39 of the Electricity Act, 2003 outlines that the functions of the State Transmission Utility shall be –

- (a) to undertake transmission of electricity through intra-State transmission system;
- (b) to discharge all functions of planning and co-ordination relating to intra-state transmission system with-
  - (i) Central Transmission Utility;
  - (ii) State Government;
  - (iii) Generating Companies;
  - (iv) Regional Power Committees;
  - (v) Central Electricity Authority;
  - (vi) Licensees;
  - (vii) any other person notified by the State in this behalf;
- (c) to ensure development of an efficient, coordinated and economical system of intra-State transmission lines for smooth flow of electricity from a generating station to the load centers;
- (d) to provide non-discriminatory open access to its transmission system for use by-
  - (i) any licensee or generating company on payment of the transmission charges; or
  - (ii) any consumer as and when such access is provided by the State Commission under sub-section (2) of section 42 of the Act, on payment of the transmission charges and a surcharge thereon, as may be specified by the State Commission.

### 2.3 State Load Despatch Center (SLDC)

#### (a) Establishment of SLDC:

The State Government of Sikkim shall establish a Centre, in terms of Section 31 of Electricity Act, 2003 to be known as the **State Load Despatch Centre (SLDC)**. The State Load Despatch Centre shall be operated by a Government company or any Authority or Corporation established or constituted by or under any State Act, as may be notified by the Government. Until a Government Company or any Authority or Corporation is notified by the State Government, the State Transmission Utility shall operate the State Load Despatch Centre. Adequate autonomy shall be provided to the State Load Dispatch Centre to discharge its functions.

#### (b) Functions of SLDC:

- 1) The State Load Despatch Centre shall be the apex body to ensure integrated operation of the power system in the State.

- 2) The State Load Despatch Centre shall discharge the functions assigned to it under the Act and in this State Grid Code, in an independent and unbiased manner.
  - 3) In accordance with section 32 of Electricity Act, 2003, the State Load Despatch Center shall -
    - (a) be responsible for optimum scheduling and despatch of electricity within the State, in accordance with the contracts entered into with the licensees or the generating companies operating in the State;
    - (b) monitor grid operations;
    - (c) keep accounts of the quantity of electricity transmitted through the State grid;
    - (d) exercise supervision and control over the intra-State transmission system; and
    - (e) be responsible for carrying out real time operations for grid control and dispatch of electricity within the State through secure and economic operation of the State grid in accordance with the Grid Standards and the State Grid Code.
  - 4) The State Load Despatch Centre may levy and collect such fee and charges from the generating companies and licensees engaged in intra-State transmission of electricity as may be specified by the Commission.
  - 5) In accordance with Section 33 of the Electricity Act, 2003, the State Load Despatch Center may give such directions and exercise such supervision and control as may be required for ensuring the integrated grid operations and for achieving the maximum economy and efficiency in the operation of power system. Every licensee, generating company, generating station, sub-station and any other person connected with the operation of the power system shall comply with the directions issued by the State Load Despatch Center under sub-section (1) of Section 33 of the Electricity Act, 2003.
  - 6) The State Load Despatch Center shall comply with directions of the Regional Load Despatch Centre.
  - 7) In case of inter-state bilateral and collective short-term open access transactions having a state utility or an intra-state entity as a buyer or a seller, SLDC shall accord concurrence or no objection or a prior standing clearance, as the case may be, in accordance with the Central Electricity Regulatory Commission (Open Access in inter-state Transmission) Regulations, 2008 amended from time to time.
- (c) **Manning of SLDC**
- i) The State Load Despatch Centre shall be manned by qualified and experienced engineers who are well acquainted with the State Transmission System and Grid Operations.
  - ii) Periodical Training shall be imparted to the personnel of the State Load Despatch Centre to update their skills in order to enable them to discharge their functions stipulated under Section 32 & 33 of the Act.

## 2.4 Implementation of the State Grid Code

- 1) The State Transmission Utility and the State Load Despatch Centre shall be responsible for implementation of the State Grid Code. All the Users shall comply with the provisions of this State Grid Code and assist the State Transmission Utility and the State Load Despatch Centre in all aspects. The Users must provide all the required information required for implementation of the State Grid Code.
- 2) If any User has any difficulty in complying with or any of the provisions of the State Grid Code, he shall, without delay, inform the same to the State Transmission Utility for guidance in complying with the provision.
- 3) The operation of the State Grid Code shall be reviewed regularly by the State Grid Code Review Committee in accordance with the provisions of the relevant section of the State Grid Code.

- 4) All the Users shall provide such reasonable cooperation and assistance as STU / SLDC may sought for and required by them. The STU / SLDC shall however refer all such cases for ratification in the next meeting of the review panel.

## **2.5 Non - compliance of State Grid Code**

- 1) If any User fails to comply with any provision of the State Grid Code, the STU shall inform the State Grid Code Review Committee without delay the reasons for its non-compliance and ensure its compliance promptly.
- 2) The SLDC shall report to the State Grid Code Review Committee, instances of serious violation of any provisions of the SGC and incidences of persistent non-compliance of the directions of the SLDC issued in order to exercise supervision and control required for ensuring stability of grid operations.
- 3) Consistent failure to comply with the State Grid Code provisions may lead to disconnection of the User's plant and / or facilities from the grid. The responsibility for the consequences of disconnection including payment of damages and compensation to consumers rests with the User who consistently violates the State Grid Code.

## **2.6 Code responsibilities**

- 1) In discharging its duties under the State Grid Code, STU has to rely on information, which Users shall supply regarding their requirements and intentions.
- 2) The STU shall exercise strict supervision over the Users to ensure compliance with the instructions issued by SLDC for efficient discharge of the Grid operations.

## **2.7 Confidentiality**

- 1) Under the terms of the State Grid Code, STU will receive information from Users relating to their intentions in respect of their Generation or Supply businesses.
- 2) STU shall not, other than as required by the State Grid Code, disclose such information to any person other than Central or State Government without the prior written consent of the provider of the information.

## **2.8 Directives from State Government**

The State Government may issue policy directives in any matter to STU or SLDC as the case may be, to take such measures as may be necessary for maintaining smooth and stable transmission and supply of electricity to any region of State as per Section 37 of the Electricity Act, 2003. STU shall promptly inform the Commission and all Users of the requirement of such directives. The Users, subject to the relevant sections of the Act, shall comply with all such directives.

## CHAPTER - 3: MANAGEMENT OF STATE GRID CODE

### 3.1 Management of State Grid Code

The State Transmission Utility (STU) is required to implement and comply with the State Grid Code and to carry out periodic review and amendments of the same with the approval of the Commission

### 3.2 State Grid Code Review Committee

- 1) A State Grid Code Review Committee shall be constituted by STU, comprising of the representatives of the State Constituents of the State Transmission System within thirty days from the date of notification of the State Grid Code Regulations.
- 2) The Chairperson of the State Grid Code Review Committee shall be an engineer of the STU not below the rank of Superintending Engineer. The Member Secretary of the Review Committee shall also be nominated by STU. The Review Committee shall also consist of the following members as recommended by the heads of the respective organizations:
  - (a) One representative from the State Government connected with Electricity affairs of the State.
  - (b) One representative at executive level from the concerned Regional Load Despatch Centre
  - (c) One representative at executive level from the State Load Despatch Centre.
  - (d) One representative at executive level from Distribution System of the State.
  - (e) One representative at executive level from each of the generating companies feeding not less than 10 MW to the State Grid.
  - (f) One representative from small generating stations of less than 10 MW capacity on rotation basis.
  - (g) Any other person as may be nominated by the Commission.
- 3) The Member Secretary nominated by STU shall be the convener and he shall coordinate the functioning of the State Grid Code Review Committee.
- 4) The STU shall inform all the Users, the names and addresses of the Review Committee Chairperson and the Member Secretary. Any subsequent changes shall also be informed to all the Users by STU. Similarly, each User shall inform the names and designations of their representatives to the Member Secretary of the Review Committee.

### 3.4 Functions of the State Grid Code Review Committee

The functions of the State Grid Code Review Committee are as follows:

- (a) Implementation of the State Grid Code, and continuous scrutiny and review.
- (b) Consideration of all requests for review proposed by any User and publication of the recommendations for changes in the State Grid Code together with reasons for such changes.
- (c) Consideration of the problems raised by any User as well as resolution of the problems.
- (d) Ensuring that the changes / modifications proposed in the State Grid Code are consistent and compatible with Indian Electricity Grid Code (IEGC).
- (e) To constitute a sub committee (**Protection Coordination Committee**) with engineers having adequate experience in Transmission System Protection from STU, Generating

- companies and Distribution Licensees. The Protection Coordination Committee shall also be responsible for all the protection coordination functions specified in this State Grid Code.
- (f) Such other matters as may be directed by the Commission from time to time.

The State Grid Code Review Committee may hold any number of meetings as required subject to the condition that at least one meeting shall be held once every six (6) months. Sub-meetings may be held by STU with the Users whenever required to discuss individual requirements to prepare proposals for Review Committees consideration.

### **3.5 Functions of the Protection Coordination Committee**

The main functions, of the Protection Coordination Committee are as follows:

- (a) Create awareness about various issues related to protection requirements for any equipment connected to the Intra-State Transmission System.
- (b) Review and specify the minimum protection requirements for the User's system connected to the Intra-State Transmission System.
- (c) Deliberate and decide in various settings, testing procedure and periodicity of testing of the protection relays.
- (d) Deliberate and decide regarding upgradation of protection schemes and switchgear equipment.
- (e) Review and analyze the reasons for failure of protection system in case of any grid disturbances and recommend methods for improvement.
- (f) Investigate into any malfunctions of protection equipment or other unsatisfactory protection issues.
- (g) Consider the requests of Users for amendment to any protective conditions specified in the State Grid Code.

The Protection Co-ordination Committee shall meet whenever requested by STU / SLDC or atleast once in every three months and shall give their recommendations, if any, to the State Grid Code Review Committee.

### **3.6 Review and Revisions**

- 1) State Grid Code shall be reviewed by the State Grid Code Review Committee atleast once in every twelve (12) months.
- 2) No change in the State Grid Code shall be made without being deliberated and agreed by the State Grid Code Review Committee and approved by the Commission.
- 3) The Users seeking any amendment to the State Grid Code shall send written requests to the Member Secretary of the State Grid Code Review Committee.
- 4) The Member Secretary shall place all the proposed revisions for the State Grid Code to the Review Committee for its consideration.
- 5) After discussion in the review meeting, the State Grid Code Review Committee shall send a report to the STU / Commission, providing information regarding:
  - (i) Outcome of the review;
  - (ii) Any proposed revisions to the State Grid Code; and
  - (iii) Copies of all written representations received from by the Users;
- 6) The STU shall send its recommendations regarding the proposed modification(s)/ amendment(s) on the report along with all the related correspondence to the Commission for approval.
- 7) Amendments to the State Grid Code shall be finalized and notified by the Commission duly adopting the prescribed procedure followed for regulations issued by the Commission.
- 8) After the approval by the Commission, the STU shall publish revisions to the State Grid Code and forward copies of approved amendments to all Users.

- 9) The STU shall maintain copies of the State Grid Code with the latest amendments and shall make them available at a reasonable cost to any person requiring it. This may also be made available on the website as soon as feasible. The STU shall keep an upto date list of recipients of all the copies of the State Grid Code, to ensure that the latest version of State Grid Code reaches to all concerned.
- 10) The Commission, may, on the application by the User or otherwise, call the emergency meeting of the Grid Code Review Committee as and when required and make such alterations or amendments in the State Grid Code as it thinks fit.

## **CHAPTER - 4: TRANSMISSION SYSTEM PLANNING**

### **4.1 State Transmission System Planning**

The State Transmission Utility (STU), in accordance with Section 39 (2) (b) of Electricity Act, 2003, shall discharge all functions of planning and coordination relating to Intra-State transmission system with Central Transmission Utility, State Government, Generating Companies, Regional Power Committee, Central Electricity Authority, Licensees and any other person notified by the State Government in this behalf.

The State Transmission System planning is essential to ensure an efficient, coordinated, secure and economical State Transmission System, to satisfy the requirements of future demand.

### **4.2 Development of State Transmission System**

- 1) Requirement for reinforcement or extension of the State Transmission system arises due to many reasons, including but not limited to the following:
  - i) Developments / changes occurring on a User's system already connected to the State Transmission System.
  - ii) Introduction of a new connection point between the User's system and the State Transmission System.
  - iii) System of evacuation of power from generating stations within or outside the State
  - iv) Reactive power compensation.
  - v) Need to increase system capacity, to remove operational constraints and to maintain standards of security to accommodate a general increase in the demand.
  - vi) Transient and steady state stability considerations.
  - vii) Cumulative effect of any combination of the above.

The reinforcement or extension of the State Transmission System may involve work at an entry or exit point (connection point) of a User to the State Transmission System.

- 2) Development of State Transmission system must be planned well in advance to ensure constituents and way leaves to be obtained and detailed engineering design / construction work to be completed. To this effect, the system planning code imposes time lines for exchange of necessary information between STU and Users.

### **4.3 Planning Policy**

- 1) Central Electricity Authority (CEA) would formulate perspective transmission plan for inter-State transmission system as well as intra-State transmission system. The State Transmission Utility (STU) shall carry out planning process from time to time as per the requirement for identification of major intra-State transmission system including inter-State transmission system which shall fit in with the perspective plan developed by the CEA.



- 2) The STU shall also plan, from time to time, system strengthening schemes, to overcome the constraints in power transfer and to improve the overall performance of the grid. The transmission system plan shall also include information related to additional equipment including transformers, capacitors, reactors, Static VAR Compensators etc.
- 3) The intra-State transmission proposals including system strengthening schemes identified on the basis of the planning studies shall be discussed, reviewed and finalized in the meetings of Grid Code Review Committee. Based on above, the STU shall come out with a transmission system plan.
- 4) The information on targets set in the preceding plans and progress achieved on the identified intra-State/inter-State transmission schemes and system strengthening schemes shall also be included in the transmission system plan.
- 5) The STU for the purpose of preparing the transmission system plan, may seek from State Constituents such information as may be required by it, including generation capacity addition, system augmentation and long-term load forecast and all (approved/pending) applications for open access.
- 6) The STU shall also consider the following for the purpose of preparing the transmission system plan;
  - (i) Plans formulated by the Central Electricity Authority for the transmission system under the provisions of clause (a) of Section 73 of the Act;
  - (ii) Electric Power Survey of India.
  - (iii) Grid Standards specified by the Central Electricity Authority under clause (d) of Section 73 of the Act.
  - (iv) Transmission Plan formulated by Central Transmission Utility under the provisions of Indian Electricity Grid Code specified by Central Electricity Regulatory Commission;
  - (v) Transmission Planning Criteria and Guidelines issued by the Central Electricity Authority;
  - (vi) Recommendations/inputs, if any, of the Eastern Regional Power Committee;
  - (vii) Reports on National Electricity Policy which are relevant for development of ISTS; and
  - (viii) Any other information/data source suggested by the Commission.
- 7) All State Constituents and agencies will supply to the STU, the desired planning data from time to time to enable it to formulate and finalize its plan.
- 8) The STU shall send a copy of transmission system plan to the Commission by 31st December each year and also place it on its website. The STU shall also make the same available to any person upon request.

#### **4.4 Planning Criteria**

- 1) The planning criteria shall be based on the security philosophy on which both Inter-State Transmission System (ISTS) and the Intra-State Transmission System (STS) have been planned. The security philosophy may be as per the Transmission Planning Criteria and other guidelines given by Central Electricity Authority.  
The STU shall carry out appropriate system studies while developing the transmission system plan.
- 2) The State Transmission System, as a general rule, shall be capable of withstanding and be secured against the following contingency outages without necessitating load shedding or rescheduling of generation during steady state operations:
  - i) Outage of a 66 kV / 132 kV D/C line or,
  - ii) Outage of a 220 kV D/C line or,
  - iii) Outage of a 400 kV S/C line or,
  - iv) Outage of a single Interconnecting Transformer

The above contingencies shall be considered assuming a pre-contingency system depletion (Planned outage) of another 66 kV or 132 kV or 220 KV D/C line or 400 kV S/C line in another corridor and not emanating from same sub-station.

- 3) The planning study would assume that all the generating units may operate within their reactive capability curves and the network voltage profile are also maintained within voltage limits specified.
- 4) The State Transmission System shall be capable of withstanding the loss of most severe single system in feed without loss of stability.
- 5) Any one of the events defined above shall not cause:
  - (i) Loss of supply;
  - (ii) Prolonged operation of the system frequency below and above specified limits;
  - (iii) Unacceptable high or low voltage;
  - (iv) System instability;
  - (v) Unacceptable overloading of State Transmission System elements
- 6) In all EHV sub-stations (66 kV and above), suitable number (atleast two) and appropriate capacity transformers shall be provided to have reliability.
- 7) The STU shall carry out planning studies for Reactive Power compensation of State Transmission System including reactive power consumption requirement at the State Generating Stations switchyard.

#### **4.5 Planning responsibility**

- 1) The primary responsibility of load forecasting within distribution licensee's area of supply rests with the respective Distribution Licensees. The Distribution Licensee shall determine peak load and energy forecast of their areas for each category of loads for each of the succeeding 5 years and submit the same annually by 30<sup>th</sup> April to STU along with details of demand forecasts, data, methodology and assumptions on which forecasts are based along with their requirement for transmission system augmentation.
- 2) Generating stations shall provide their generation capacity to STU for evacuating power from their power stations for each of the succeeding 5 years along with their requirement for augmentation of transmission proposals and submit the same annually by 30<sup>th</sup> April to STU.
- 3) The planning for strengthening the State Transmission System for evacuation of power from generating stations of outside State shall be initiated by STU.

#### **4.6 Planning data**

State Generating Companies / IPPs / licensees shall supply following types of data to STU for the purpose of developing transmission plan:

- (i) Standard Planning Data
- (ii) Detailed Planning Data

##### **(a) Standard Planning Data:**

- i) Standard Planning data shall consist of details which are expected to be normally sufficient for the STU to investigate the impact on the State Transmission System (STS) due to User / Transmission Licensee development.
- ii) The Transmission Licensees and Users shall provide the following standard planning data to STU from time to time in the standard formats prescribed by STU.
  - (a) preliminary project planning data,
  - (b) committed project planning data and
  - (c) connected planning data.

**(b) Detailed Planning data:**

- i) Detailed Planning data shall consist of detailed data required by STU to assess the impact of User's / Transmission Licensee's development on the State Transmission System.
- ii) The detailed planning data shall be furnished by the Users and Transmission Licensees as and when requested by STU.

**(c) Formats:**

- i) The formats for submission of the above data are given in Appendices.
- ii) The one time data shall be submitted by all the Users and Transmission Licensees to STU within six (6) months from the date of notification of this State Grid Code.
- iii) STU shall also furnish to all the Users, the Annual Transmission Planning Report, Grid Map and any other information as the Commission may specify.

**4.7 Implementation of Transmission Plan**

The actual programme of implementation of transmission lines, inter-connecting transformers, reactors/capacitors and other transmission elements will be determined by STU in consultation with the concerned users. The completion of these works within time frame shall be ensured by STU through the concerned agencies.

## **CHAPTER - 5: CONNECTION CONDITIONS**

**5.1 General Connectivity Conditions**

- 1) The Requester shall be responsible for the planning, design, construction, reliability, protection and safe operation of its own equipment.
- 2) The Requester and User shall furnish data as required by the State Transmission Utility or by the licensee or generating station with whose system the inter-connection is proposed, for permitting interconnection with the Grid.
- 3) The Requester and user shall provide necessary facilities for voice and data communication and transfer of on-line operational data, such as voltage, frequency, line flows, and status of breaker and isolator position and other parameters as prescribed by the State Load Despatch Centre.
- 4) The Requester and User shall cooperate with State Load Despatch Centre in respect of the matters listed below, but not limited to:
  - (a) protection coordination and settings of its protective relays accordingly;
  - (b) agree to maintain meters and communication system in its jurisdiction in good condition;
  - (c) participate in contingency operations such as load shedding, increasing or reducing generation, islanding, black start, providing start-up power and restoration as per the procedure decided by the State Load Despatch Centre;
  - (d) furnish data as required by State Transmission Utility or Transmission Licensee, State Load Despatch Centre, Eastern Regional Power Committee, and any committee constituted by the Commission or Government for system studies or for facilitating analysis of tripping or disturbance in power system;
  - (e) carryout modifications in his equipment with respect to short circuit level, protection coordination and other technical reasons considered necessary due to operational requirements;
  - (f) abide by the coordinated outage plan of the state and region in respect of generating units and transmission lines as approved by the State Load Despatch Centre;

## **5.2 Procedure for connection to the State Transmission System**

- 1) Application for establishing new arrangement or modification of existing arrangement of connection to and / or use of the State Transmission System shall be submitted by the concerned Requester / User to the State Transmission Utility (STU).

The standard format for application shall be developed by State Transmission Utility and shall be made available at its office and in its website within two (2) months of notification of this State Grid Code Regulations, 2012.

- 2) The above application shall be submitted along with the following details:
  - (i) Purpose of the proposed connection or modification, transmission licensee to whose system connection is proposed, connection point, description of apparatus to be connected or modification of the apparatus already connected and beneficiaries of the proposed connection;
  - (ii) Construction schedule including completion date, and
  - (iii) Confirmation that the User shall abide by the provisions of State Grid Code.
- 3) The STU shall forward a copy of the application to the concerned Transmission Licensee in whose system the connection is being sought and to the State Load Despatch Centre for their comments.
- 4) The STU or the Transmission licensee, in whose system the connection is being sought, may carry out the power system studies as considered appropriate before allowing any new connection.
- 5) The STU shall, within thirty (30) days, from the receipt of an application and after considering all suggestions and comments received from the parties identified under para (3) above accept the application with such modification or such conditions as may be specified by the STU.
- 6) On acceptance of an application, the STU shall make a formal offer to the applicant for consent, specifying any works required for the extension or reinforcement of the State Transmission System necessitated by the applicants proposal.

A copy of the offer shall be forwarded to the concerned Transmission Licensee.

- 7) The STU shall, upon compliance of the required conditions by the User, shall notify the concerned User, that it can be connected to the State Transmission System.
- 8) The applicant and the concerned Transmission Licensee or STU, in whose system the connection is being sought, shall finalise a Connection Agreement on acceptance of the offer by the applicant. A copy of the Connection Agreement shall be provided to the STU and SLDC.

## **5.3 Rejection of application**

- 1) The STU shall be entitled to reject any application for connection to the State Transmission System for reasons, to be recorded in writing, if such application is not in accordance with the provisions of the State Grid Code.
- 2) In the event of any dispute with regard to rejection of application by STU, the User may approach the Commission

#### **5.4 Connection Agreement**

- 1) All Users connected to or Requesters seeking connections to the Grid shall enter into connection agreement with the STU.  
A connection agreement, shall include within its terms and conditions, the following:
  - (i) A condition requiring both parties to comply with the provisions of the State Grid Code.
  - (ii) Details of connection, technical requirements and commercial arrangements.
  - (iii) Details of any capital related expenditure arising from reinforcement or extension of the system, data communication etc, and demarcation of the same between the concerned parties.
  - (iv) Details of Plants and equipments to be connected.
  - (v) A Site Responsibility Schedule.
  - (vi) Any other information considered appropriate by the STU or the Commission.
- 2) The STU shall develop a model Connection Agreement within two months and submit to the Commission for approval.

#### **5.5 Site Responsibility Schedule**

- 1) For every connection to the State Transmission System for which a connection agreement is required, the User shall prepare a schedule called 'Site Responsibility Schedule' indicating the following for each item of equipment installed at the connection site.
  - i) Ownership of the equipment
  - ii) Responsibility for control of equipment
  - iii) Responsibility for maintenance of equipment
  - iv) Responsibility for operation of equipment
  - v) Responsibility for all matters relating to safety of any person at the connection / interface site.
  - vi) Management of the Connection / Interface site.
- 2) The format to be used in the preparation of Site Responsibility Schedule is given in Appendix – C in the Data Registration Chapter.

#### **5.6 Access to Connection Site**

The Requester or User, as the case may be, owning the electrical plant shall provide reasonable access and other required facilities to the State Transmission Utility or State Load Despatch Centre, whose equipment is installed or proposed to be installed at the Connection Site for installation, operation and maintenance etc, of the equipment.

#### **5.7 Site Common Drawings**

Site Common Drawings shall be prepared for each connection point by the owner of the sub-station where connection is taking place.

#### **5.8 System Performance**

- 1) The Design and Construction of all the equipment connected to the State Transmission System shall satisfy the relevant Indian Standard Specifications. In case of equipment for which Indian Standard Specifications do not exist, the appropriate IEC, or IEEE or other International Standards shall apply.

- 2) Installation of all electrical equipment shall comply with IE Rules, 1956 which are in force for time being or as replaced by new rules made under Electricity Act, 2003.
- 3) For every new / modified connection sought the STU shall specify the connection point, technical requirements and the voltage to be used, along with protection and metering requirements as specified in the Protection System (Chapter-6) and Metering (Chapter-15).
- 4) Insulation coordination of the User's equipment shall conform to those applicable as per Indian Standards. Rupturing capacity of the switchgear shall not be less than that specified as per Indian Standards.
- 5) Protection schemes and metering schemes shall be as detailed in the Protection and Metering Chapters.
- 6) The State Transmission System rated frequency shall be 50.00 Hz and shall normally be controlled within the limits as per Regulations issued by the Authority.
- 7) The User shall be subject to the Grid discipline prescribed by SLDC and ERLDC.

## **5.9 Connection Points / Interface points**

### **1) State Generating Station (SGS) / IPPs / CPPs:**

- The voltage at the Connection point / Interface point with the State Transmission System may be 220/132/66 KV or as agreed with STU.
- Unless specifically agreed with STU, the Connection point with generating station shall be the terminal isolator provided just before the outgoing gantry of the feeders.
- Generating stations shall operate and maintain all terminals, communication and protection equipments provided within the generating station.
- The provisions for the metering between generating station and STU system or Transmission licensee system shall be as per the Metering Code.
- Respective Users shall maintain their equipment from the going out feeders' gantry onwards emanating from generating station

### **2) Distribution Licensee:**

- The voltage at the Connection Point / Interface Point to State Transmission System may be as specified by the Distribution Licensee or as agreed with STU.
- Unless specifically agreed with Distribution Licensee, the Connection point with STU shall be the outgoing feeder gantry from STU sub-station.
- STU shall operate and maintain all terminals, communication and protection equipments provided within its sub-station.
- The provisions for the metering between Distribution Licensee and STU systems shall be as per the Metering Code.
- Respective Users shall maintain their equipment beyond the out going gantry of feeders emanating from STU sub-station onwards.

### **3) Regional Transmission System:**

- The Connection, protection scheme, metering scheme and the voltage shall be in accordance with the provisions of IEGC.

### **4) EHV Consumers and Open Access Customers:**

- The voltage may be 220/132/66 KV or as agreed with STU.
- The Connection point shall be just before the feeder gantry in their premises. The metering point shall be Connection point / Interface Point with their system.



#### **5.10 General conditions for Connectivity of renewable energy generating station to the grid**

- i) A generating station of renewable sources can be connected at the distribution level (below 33 kV) or transmission level (at or above 33 kV) of the State.

##### **Explanation**

*If connected at distribution level, it along with fluctuating load, may even out fluctuations that get reflected on to the transmission system.*

*If a group of renewable generators are connected at the transmission level of the State, then the fluctuations of generation of various renewable generators would be evened out to get reflected as lesser fluctuations over the STU system at higher voltage level.*

#### **5.11 Data requirements:**

- 1) All the Users shall provide STU with data as specified in the Data Registration Chapter.
- 2) Unless otherwise agreed in Connection Agreement, the equipment for data transmission and communication shall be operational and maintained by the User in whose premises it is installed irrespective of its ownership.

## **CHAPTER - 6: PROTECTION SYSTEM**

### **6.1 General Principles**

- 1) Protection system is an important technical requirement for connectivity to the grid. No item of electrical equipment shall be allowed to remain connected to the State Transmission System unless it is covered by minimum specified protection relay settings aimed at reliability, selectivity, speed, stability and sensitivity.
- 2) All Users shall co-operate with STU to ensure correct and appropriate settings of protection to achieve effective, discriminatory removal of faulty equipment within the target clearance time specified in this section.
- 3) Protective Relay settings shall not be altered, or protection relays bypassed and/or disconnected without consultation and agreement between all Users. In case where protection is bypassed and/or disconnected by an agreement, then the cause must be rectified and the protection restored to normal condition as quickly as possible. If agreement has not been reached, that electrical equipment which is not having protection shall be removed from service forthwith.

### **6.2 Protection Coordination**

- 1) The settings of protective relays starting from the generating unit upto the remote end of 66 KV line shall be such that only the faulty section is isolated under all circumstances. The STU shall notify the initial settings and any subsequent changes approved by the Protection Coordination Committee to the Users from time to time. Periodical testing of all the protective relays shall be conducted once in six months.
- 2) Malfunctioning of any protective relay shall be intimated to the Protection Coordination Committee immediately for analyzing and to recommend necessary corrective actions.
- 3) A separate cell headed by an engineer of executive level, having experience in protection of system and consisting of necessary supporting technical and non-technical staff shall be established by the STU, for testing and maintenance of protection relays, meters and other connected instruments.

- 4) At all places where protection schemes are installed, they have to be exhibited in single line diagram.
- 5) Copies of the specifications of all the protection relays installed shall be provided at all places where such relays are installed.

### **6.3 Fault Clearance Times**

- 1) The fault clearance time when all equipment operate correctly, for a three phase fault (close to the bus bars) on user equipment directly connected to State Transmission System and for a three phase fault (close to bus bars) on State Transmission Connected to the users equipment, shall not be more than;
  - a) 160 milliseconds for 220 kV and 132 kV class of voltage
  - b) 300 milliseconds for 66 kV class of voltage
- 2) Lesser fault clearance time than the above are preferable.
- 3) Lower fault clearance times for faults on a Users system may be agreed to but only if, in STU's opinion, system conditions allow this. STU shall specify the required opening time and rupturing capacity of the circuit breakers at various locations for STU and Distribution Licensees / Open Access Customers directly connected to Transmission System. At generating stations, line faults should be cleared at the generation station end within the critical clearing time so that the generators remain in synchronism.

### **6.4 Protection requirements for Generating Units**

All Generating Units and all associated electrical equipment of the Generating Units connected to the intra-State transmission system shall be protected by adequate protection so that the intra-State transmission system does not suffer due to any disturbances originating from the Generation units. The generator protection schemes shall cover at least Differential protection, back up protection, Stator Earth fault protection, field ground/field failure protection (not applicable to brush-less excitation system), negative sequence protection, under frequency, over flux protection, back up impedance protection and pole slipping protection (applicable to units above 200 MW), loss of field protection, reverse power protection etc.

### **6.5 Protection requirements for Transmission Line**

#### **1) General**

Every EHT line taking off from a Generating Station or a sub-station or a switching station shall have adequate protection and back up protection as mentioned below.

Switchgear equipment and Relay Panels for the protection of lines of STU taking off from a Generating Station shall be owned and maintained by the Generator. Any transmission line related relay settings or any change in relay settings will be carried out by the Generator in close co-ordination and consultation with STU. Carrier cabinets / equipment, Line matching units including wave traps and communication cables shall be owned and maintained by STU. All Generators shall provide space, connection facility, and access to STU for such purpose.

#### **2) 220 KV Transmission Lines**

All 220 KV transmission lines owned by STU shall have two fast acting protection schemes.

Main-1 protection scheme shall be numeric, three zone, non-switched fast acting distance protection scheme with permissible inter-trip at remote end (in case of zone-2 fault). The scheme shall have power swing blocking, location of fault recording, disturbance recording, event logger, communication port, single and three shot auto reclosing as well as Local Breaker Backup (LBB).

Main-2 protection scheme shall be static/ numeric, three zone, switched/ non-switched fast acting distance protection scheme having all features as in Main- 1 except auto reclosing and Local Breaker Backup (LBB).

For back-up protection, three directional IDMTL over current relays and unidirectional earth fault relay shall be provided.

### **3) 132 KV/66 KV Lines**

A single scheme three zone, non-switched numeric distance protection with standard built in features like single and three phase tripping, carrier inter-tripping, IDMT over current and earth fault, power swing blocking and LBB protection shall be provided as main protection.

The backup protection shall be at least two directional IDMTL over current relays and one directional earth fault relay.

For short transmission radial lines, appropriate alternative protection schemes may be adopted.

## **6.6 Protection requirements for Transformer**

1) The following minimum protections shall be ensured for transformers:

- (i) All 220 KV class power transformers shall be provided with numeric fast acting differential, REF, open delta (Neutral Displacement Relay) and over-fluxing relays. In addition, there shall be back up IDMTL over current and earth fault protection. For parallel operation, such back up protection shall have inter-tripping of both HV and LV breakers. For protection against heavy short circuits, the over current relays should incorporate a high set instantaneous element. In addition to electrical protection, transformer own protection viz. buchholz, OLTC oil surge, gas operated relays, winding temperature protection, oil temperature protection, PRV relay shall be provided for alarm and trip functions.
- (ii) For 132 KV and 66 KV class power transformers of capacity of 10 MVA and above; the protection shall be same as mentioned in 7.6(i) above except over-fluxing, Restricted Earth Fault (REF) and Pressure Relief Valve (PRV) relays.
- (iii) For 132 KV and 66 KV class power transformers of capacity less than 10 MVA, over-current with high set instantaneous element along with auxiliary relays for transformer trip and alarm functions as per transformer requirements, shall be provided.

2) In addition to electrical protection, gas operated relays, winding temperature protection and oil temperature protection shall be provided.

## **6.7 Fire Protection of Sub-Station**

Adequate precautions shall be taken and protection shall be provided against fire hazards to all apparatus and other assets conforming to relevant Indian Standard Specification and provisions in I.E. Rules. The fire fighting equipment installed shall be maintained in good working condition and shall be inspected daily and recorded in the maintenance logbook by the concerned in-charge person. The single line schematic diagram of the fire protection arrangement shall be displayed in the sub-station control room.

## **6.8 Calibration and Testing**

The protection scheme shall be tested at each 220 KV, 132 KV, 66 KV sub-station by STU and Users once in six months or immediately after any major fault, whichever is earlier. Testing and calibration of all protection schemes pertaining to generating units/stations shall be the responsibility of respective SGS.

## **6.9 Data requirements**

Users shall provide to the STU and SLDC with data as specified in Appendix-D.

## **CHAPTER - 7: SYSTEM SECURITY ASPECTS**

### **7.1 System Security**

- 1) All State Constituents shall endeavor to operate their respective power systems and generating stations in synchronism with each other at all times, such that the State Grid operates as synchronized system and integrated part of Concerned Regional Grid. The STU shall endeavor to operate the inter-state links in such a way that transfer of power can be achieved smoothly when required. Security of the power system and safety of power equipment shall enjoy priority over economically optimal operations.
- 2) All switching operations, whether affected manually or automatic, will be based on policy guidelines of:
  - i) IEGC
  - ii) ERLDC's instructions/guidelines
  - iii) State Grid Code
- 3) No part of the State Transmission System shall be deliberately isolated from the integrated grid except under the following conditions;
  - i) Under emergency conditions in which such isolation would prevent a total grid collapse and / or would enable early restoration of power supply
  - ii) When serious damage to a costly equipment is imminent and such isolation would prevent it and
  - iii) When such isolation is specifically instructed by SLDC.
- 4) In case of isolating of any important element of the State Transmission System under an emergency situation, the same shall be intimated to SLDC at the earliest possible time after the event.
- 5) Complete synchronization of grid shall be restored as soon as the conditions permit it. The restoration process shall be supervised by SLDC.
- 6) Any tripping, whether manual or automatic of any transmission lines of 66 KV and above or power transformers of 66 KV and above of State Grid shall be promptly reported to the SLDC at the earliest along with the reasons for such tripping and the likely time required for restoration. While restoring the tripped equipment / line, the SLDC shall be informed and get the clearance.
- 7) Each User and Transmission Licensee shall provide adequate and reliable communication facility internally and with the SLDC, other Users and other Transmission Licensees to ensure exchange of data/information necessary to maintain reliability and security of the grid.
- 8) The User and State Transmission Utility shall provide the requested information/data including disturbance recorder/sequential event recorder output etc to State Load Despatch Centre for purpose of analysis of any grid disturbance/event.

## CHAPTER - 8: FREQUENCY AND VOLTAGE MANAGEMENT

### 8.1 Frequency Management

- 1) The rated frequency of the system shall be 50 Hz and shall normally be controlled within the limits specified by the Central Electricity Authority (CEA). STU and SLDC shall make all possible efforts to ensure that grid frequency remains within 49.5 – 50.2 Hz. Frequency band is tightened in the Indian Electricity Grid Code (IEGC) 2010 from 49.2 – 50.3 Hz to 49.5 – 50.2 Hz, in the interest of grid security and to ensure better power quality.

#### Falling Frequency

- 2) Under falling frequency conditions, SLDC shall take appropriate action to issue instructions, in co-ordination with ERLDC, to arrest the falling frequency and restore frequency within permissible range. Such instructions may include despatch instruction to State Generating Stations to increase generation and/or instruction to Distribution Licensees and Open access customers to reduce load demand by appropriate manual and/or automatic load shedding.
- 3) Users and Transmission Licensees shall provide automatic under frequency and df/dt relay-based load shedding/islanding schemes in their respective systems, wherever applicable, to arrest frequency decline that could result in a collapse/disintegration of the State grid, and shall ensure its effective application to prevent cascade tripping of generating units in case of any contingency.
- 4) Users and Transmission Licensees shall ensure that the under-frequency and df/dt relay-based load shedding/islanding schemes are always functional.

However, the relays may be temporarily kept out of service, in extreme contingencies, with prior consent of State Load Despatch Centre.

#### Rising Frequency

- 5) Under rising frequency conditions, SLDC shall take appropriate action to issue instructions to Generating stations, in co-ordination with ERLDC, to arrest the rising frequency and restore frequency within permissible range. SLDC shall also issue instructions to Distribution Licensees and Open access customers to lift Load shedding (if exists) in order to take additional load.

### 8.2 Voltage Management

- 1) Users using the Intra-State Transmission System shall make all possible efforts to ensure that the grid voltage always remains within the limits as specified in IEGC-2010

| Voltage (KV rms) |         |         |
|------------------|---------|---------|
| Nominal          | Maximum | Minimum |
| 220              | 245     | 198     |
| 132              | 145     | 122     |
| 66               | 72      | 60      |
| 33               | 36      | 30      |

- 2) The STU and/or SLDC shall carry out load flow studies based on operational data from time to time to predict where voltage problems may be encountered and identify appropriate

measures to ensure that voltages remain within the defined limits. On the basis of these studies, SLDC shall instruct SGS to maintain specified voltage level at interconnecting points.

SLDC shall continuously monitor 220 KV, 132 KV, and 66 KV voltage levels at strategic sub-stations.

- 3) The SLDC shall take appropriate measures to control Voltages at EHV Sub-stations, which may include transformer tap changing, capacitor / reactor switching capacitor switching by Distribution Licensees at 33 KV substations, and use of MVAR reserves with SGS within technical limits agreed to between STU and Generators. Generators shall inform SLDC of their reactive reserve capability promptly on request.
- 4) The SLDC will ensure that there is minimum reactive power flow on transmission network. Reactive energy demand would be met by installation of capacitor banks at suitable sub-stations as per load flow study.
- 5) Distribution Licensees and Open access customers shall participate in voltage management by providing local VAR compensation (as far as possible in low voltage system close to load points) such that they do not draw VARs from the EHV grid.

## **CHAPTER - 9: OPERATION PLANNING**

### **9.1 Operation Policy**

- 1) The STU and SLDC shall periodically review the performance of the State Grid for the past period and plan stable operation of the Grid for the future, considering various parameters and occurrences such as frequency deviations, voltage profile, line loadings, Grid incidents, performance of system protection schemes.
- 2) Participant utilities shall cooperate with each other and adopt "Good Utility Practice at" all times for satisfactory and beneficial operation of the State Grid.
- 3) Overall operation of the State Grid shall be supervised by the State Load Despatch Centre (SLDC). The role of SLDC shall be in accordance with the provisions of the Act.
- 4) The SLDC shall develop, document and maintain a set of detailed internal operating procedures for managing the State Grid in consultation with State constituents and shall be consistent with State Grid Code.  
These internal operating procedures shall include the following:
  - (i) Black start procedures;
  - (ii) Load shedding procedures;
  - (iii) Islanding procedures; and
  - (iv) Any other procedures considered appropriate by the SLDC.

The above procedures shall be submitted, within three (3) months, to the Commission for approval.

- 5) The control rooms of the State Load Despatch Centre, Power Plants, Substations of 132 kV and above and any other control centres of Transmission Licensees and Users shall be manned round-the-clock by qualified and adequately trained personnel.

### **9.2 Demand Estimation for Operational Purpose**

- 1) The demand estimation is to be done on daily / weekly / monthly basis for current year for Load-Generation Balance Planning. The SLDC shall carryout system studies for operational planning purpose using this demand estimate.



- 2) The SLDC shall develop methodologies / mechanisms for daily / weekly / monthly / yearly demand estimation (MW, MVAH and MWh) for operational purposes. Based on this demand estimate and the estimated availability from different sources. SLDC shall plan demand management measures like load shedding, power cuts etc. SLDC shall also maintain historical database for demand estimation.
- 3) The long term demand estimation and load forecast (for more than 1 year) shall be done by STU. The SLDC shall be provided with a copy of the same as and when it is finalized.
- 4) It shall be the responsibility of all Distribution Licensees to fully cooperate with STU & SLDC in preparation of demand estimation and shall provide relevant data and other information as required by SLDC.
- 5) Based on the data furnished by the Distribution Licensees, STU shall make monthly peak and lean period demand estimates for year ahead and daily peak and lean period demand estimates for the month ahead and furnish the same to SLDC.
- 6) The Distribution Licensee shall provide to SLDC, estimates of loads that may be shed when required, in discreet blocks with details of arrangements of such load shedding. The Distribution Licensees shall also furnish details of essential loads, for which power cuts are to be avoided.
- 7) The monthly estimated demand by the SLDC shall be provided to RLDC and ERPC for better operation planning.

### **9.3 Demand Management (Demand Control)**

- 1) The SLDC, STU and Users shall initiate action to restrict the drawl of its control area, within the net drawal schedule whenever the system frequency falls to 49.7 Hz.
- 2) The SLDC shall ensure that requisite load shedding is carried out in its control area so that there is no over drawal when frequency falls to 49.5 Hz and there continues to be no overdrawal when frequency is 49.5 Hz or below.
- 3) Automatic load shedding shall be resorted to by means of installation of the Under Frequency Relays at the sub stations of the STU as per the directions of the SLDC to preserve the overall integrity of the power system. The number and size of the discrete blocks using Automatic Under Frequency Relays for load disconnection shall be determined on rotational basis in consultation with every Distribution Licensee. The frequency settings of these relays shall be coordinated in consultation with the ERLDC.
- 4) Whenever restoration of large portions of the total demand disconnection effected by the automatic load shedding is not possible within a reasonable time, the SLDC shall implement additional disconnection manually, to restore an equivalent amount of demand disconnected. Each Distribution Licensee shall help the SLDC in identifying such load blocks. Load disconnected by the operation of automatic load shedding devices shall not be restored without specific directions from the SLDC.
- 5) Planned manual load shedding shall be implemented by the SLDC when there is a shortfall in generation, or constraints in Transmission System, or reduction of imports through external connection etc., requiring demand control to control the over-drawl of power from ISGS. In such cases a rotational load shedding scheme shall be adopted to ensure equitable treatment for all consumers as far as practicable.
- 6) Emergency manual load shedding to deal with unacceptable voltage and frequency levels etc. shall be implemented by the SLDC when loss of generation, mismatch of generation

with the demand, constraints in the transmission system, over-drawal from the grid in excess of respective schedule affecting the frequency of the regional grid below 49 Hz, requiring load shedding at short notice or no notice, to maintain a regulating margin.

- 7) These control measures shall not be withdrawn till the system frequency improves and when the SLDC issues such instructions after review of the situation.

#### **9.4 Load Crash**

- 1) In the event of load crash in the system due to weather disturbance or any other reasons, the situation would be controlled by SLDC by the following methods in descending priorities:
  - a) Lifting of the load restrictions, if any,
  - b) Exporting the power to neighboring regions/ states,
  - c) Backing down of thermal stations with a time lag of 5-10 minutes for short period in merit order,
  - d) Closing down of hydel units (subject to non spilling of water and effect on irrigation) keeping in view the inflow of water into canals and safety of canals/hydel channels,

The above methodology shall be reviewed from time to time.

- 2) While implementing the above, the system security aspects should not be violated as per provisions in Chapter 5 of this State Grid Code.

#### **9.5 Periodic Reports**

##### **1) Weekly Reports**

A weekly report shall be put on its website by SLDC and shall cover the performance of the State Grid for the previous week. Such weekly report shall be available on the website of the SLDC for at least 12 weeks. The weekly report shall contain the following:-

- (i) Frequency profile;
- (ii) Voltage profile of important substations;
- (iii) Demand and Supply Situation;
- (iv) Major Generation and Transmission Outages;
- (v) Transmission Constraints; and
- (vi) Instances of persistent/significant non-compliance of SGC.
- (vii) Instances of inordinate delays in restoration of transmission lines and generating unit.

##### **2) Other Reports**

- i) The SLDC shall prepare a quarterly report which shall bring out the system constraints, reasons for not meeting the requirements, if any, of security standards and quality of service, along with details of various actions taken by different users, and the users responsible for causing the constraints.
- ii) The SLDC shall also provide information/report which can be called for by STU in the interest of smooth operation of STS.

#### **9.6 Written Operating Instructions:**

- 1) Written operating instructions for each equipment and operating procedure for sequence of operations of power system equipment shall be available at each sub-station and switchyard.
- 2) The operating procedure followed shall not be inconsistent with the manufacturer's instructions regarding particular items of equipment.

- 3) All operators shall be aware of all the operating instructions and procedures and be capable of operating the equipment skillfully.
- 4) These operating instructions and procedures shall be revised whenever required.

## **CHAPTER - 10: OUTAGE PLANNING**

### **10.1 Outage Planning Process**

- 1) The SLDC shall be responsible for analyzing the outage schedule given by all users (Transmission licensees / SGS) preparing a draft annual outage schedule and finalization of the annual outage plan for the following financial year.
- 2) All Users and STU shall provide SLDC with their proposed outage programmes in writing for the next financial year by 31st October of each year. These shall contain identification of each generating unit/transmission line/ICT, the preferred date for each outage and its duration.
- 3) The SLDC shall then come out with a draft outage schedule programme for the next financial year by 15<sup>th</sup> January of each year for the State Grid taking into account the draft outage plan for the State given by ERPC Secretariat. This will be done after carrying out necessary system studies and, if necessary, the outage programmes shall be rescheduled. Adequate balance between generation and load requirement shall be ensured while finalising outage programmes.
- 4) The Annual Outage Plan shall be finalized by SLDC after considering the final outage plan for the State prepared by the ERPC Secretariat and shall be intimated to all State constituents for implementation latest by 15th February of each year.
- 5) The above annual outage plan shall be reviewed by SLDC on quarterly and monthly basis in coordination with all parties concerned, and adjustments made wherever found to be necessary.
- 6) In case of emergency in the system, viz., loss of generation, breakdown of transmission line affecting the system, grid disturbances, system isolation, SLDC may conduct studies again before clearance of the planned outage.
- 7) Each State constituent shall obtain the final approval from SLDC prior to availing an outage.

### **10.2 Availing of shutdowns schedule**

- 1) The SLDC would review on daily basis the proposed outage schedule for the next two days and in case of any contingency or conditions such as;
  - (i) Major grid disturbances,
  - (ii) System isolation,
  - (iii) Partial black out,
  - (iv) or any other event in the system that may have an adverse impact as the system security by the proposed outage.
- 2) The SLDC may defer any planned outage stating the reasons thereof. The revised dates in such cases would be finalized in consultation with the User as soon as possible.
- 3) The STU and User shall obtain the final approval from SLDC prior to availing the shutdown.
- 4) Where interruption of power supply is caused to consumers due to availing of the planned shutdown, the Distribution Licensee shall give prior information to the consumers by publishing in the daily newspaper regarding the interruption of supply timings.

## **CHAPTER - 11: CONTINGENCY PLANNING**

### **11.1 Contingency Planning Procedure**

- 1) The SLDC shall be prepared to face and efficiently handle the following types of contingencies and restoration of system back to normal:
  - Partial system blackout in the state due to multiple tripping of the Transmission lines emanating from power stations/sub-stations
  - Total black out in the State/Region
  - System islands / System split
- 2) Diesel generating (DG) sets of sufficient capacity shall be provided at each power station to meet the start-up power.
- 3) Synchronizing facility shall be available at all power stations and 220 KV, 132 KV and 66 KV sub-stations having inter-connection with Inter State Transmission System.
- 4) In case of partial blackout in the system/state, priority is to be given for early restoration of power station units, which have tripped.
- 5) In case of total regional blackout, SLDC shall co-ordinate and follow the instructions of Eastern Regional Load Despatch Centre (ERLDC) for early restoration of the entire grid.
- 6) For safe and fast restoration of supply, SLDC shall formulate the proper sequence of operations for major generating units, lines, transformers and load within the state. The sequence of operations shall include opening, closing/tripping of circuit breakers, isolators, on-load tap-changers etc.

### **11.2 Restoration Procedure**

- 1) Detailed procedure for restoration of the State Grid under partial / total blackout shall be developed by SLDC in consultation with ERLDC and all Users and shall be reviewed / updated annually.
- 2) Detailed procedures for restoration under partial / total blackout of each User's system within the State will be finalized by the concerned User in co-ordination with SLDC.
- 3) List of generating stations with black start facility, inter-state / inter-regional ties, synchronizing points and essential loads to be restored on priority, shall be available with SLDC.
- 4) All communication channels required for restoration process shall be used for operational communication only till grid normalcy is restored.

### **11.3 Special considerations applicable to contingency planning**

- 1) During the process of restoration of the State Transmission System the normal standards of voltage and frequency need not be insisted and may left to the discretion of the SLDC.
- 2) Distribution Licensees shall separately identify non-essential loads, which may be kept off during system contingent conditions. They shall also draw up an appropriate schedule with corresponding load blocks in each case. The non-essential loads can be put on only when system normalcy is restored or as advised by SLDC.
- 3) All Users shall pay special attention in carrying out the procedures to prevent secondary collapse of the system due to undue haste or inappropriate loading operation of conditions.

- 4) Despite the urgency of the situation, prompt and complete logging of all operations and operational messages shall be ensured by all Users to facilitate subsequent investigation into the incident and reviewing of the efficiency of the restoration process. Such investigation shall be conducted after the incident, and placed before the Grid Code Review Committee in its next meeting.

#### **11.4 Post disturbance analysis**

The SLDC as per guidelines and instructions from ERLDC shall carry out the post-analysis of disturbance occurrence of all major grid disturbances resulting into total or partial system blackout and out of synchronization of any part of the State Grid. All users shall enable SLDC to analyze the system disturbance and furnish report to ERLDC.

### **CHAPTER - 12: OPERATIONAL EVENT INFORMATION REPORTING**

#### **12.1 Reportable Events**

- 1) All events in the State Transmission System having an operational effect on the User's system shall be reported by the STU to SLDC and to Users whose systems are affected.
- 2) All events in the User's system having an operational effect on the State Transmission System shall be reported by the User to the STU and SLDC and who inturn shall intimate the other Users on whose system the event may have an operational effect.
- 3) Any of the following incidents / events that could affect the State Transmission System requires reporting:
  - a) Exceptionally high / low system voltage or frequency.
  - b) Serious equipment problem relating to major circuit breaker, transformer or bus bar.
  - c) Failure of major Generating Units.
  - d) System split, State Transmission System breakaway or Black Start.
  - e) Tripping of transmission Line, ICT (Inter connecting transformer) and capacitor banks.
  - f) Major fire incidents.
  - g) Major failure of protection equipment.
  - h) Equipment and Transmission Line overload.
  - i) Accidents-Fatal and Non-Fatal.
  - j) Load Crash / Loss of Load
  - k) Excessive drawal deviations.

#### **12.2 Reporting Procedure**

- 1) All incidents occurring on lines and equipment above 33 kV and all the lines on which there is the inter user flow affecting the State Transmission System shall immediately be reported orally on telephone or through power line carrier communication etc by the User or STU whose equipment has experienced the incident to SLDC. The reporting User or STU shall submit a confirmation report by Telephone message / Fax / E-mail to SLDC within one hour of such oral report.

The reporting User shall submit a written report within 2 (two) days of occurrences of the incident to the SLDC by e-mail or by courier or by certified post.

- 2) The SLDC shall *suo moto* call for a report from any User on any incident affecting other Users or STU. However, this shall not relieve any User from the obligation to report events in accordance with provisions of the State Grid Code to SLDC / STU.

- 3) A written report containing the following details confirming the oral report, shall be sent to SLDC by the User or STU.

- (i) Location of incident.
- (i) Time and date of incident.
- (iii) Plant and equipment directly involved.
- (iv) Details of relay indications with nature of fault implications.
- (v) Demand / Transmission or Generation (in MW) interrupted and duration of interruption.
- (vi) Brief description and cause of incident / event.
- (vii) Estimated time to return to service.
- (viii) Possibility of alternate arrangement made for restoration of supply
- (ix) Any other relevant information

### **12.3 Reporting Form**

The standard reporting form, other than for accidents, shall be as approved from time to time by the Grid Code Review Committee. The standard reporting form shall be made available in the website of STU and SLDC. A typical form is attached (APPENDIX-F).

### **12.4 Major Incident**

Whenever a major incident such as tripping of generating unit or EHV transmission line, system frequency or voltage outside the statutory limits, system overload, accidents etc takes place, the User shall inquire and establish the cause of such failure and report to STU / SLDC / Commission. The STU shall submit the report with its comments/ remarks to State Grid Code Review Committee within one month for further analysis. On demand by the Commission a detailed report on any major incidents shall be submitted to the Commission by the STU / SLDC.

## **CHAPTER - 13: MONITORING OF GENERATION AND DRAWAL**

### **13.1 Monitoring of Generation**

- 1) For effective operation of the State Transmission System, it is important that the declared availability by a State Generating Station (SGS) is realistic and that any departures from the availability are invariably reported to the SLDC.
- 2) The SLDC shall continuously monitor Generating Unit outputs and Bus voltages. More stringent monitoring may be performed at any time when there is reason to believe that a SGS's declared availability may not match the actual availability or declared output does not match the actual output.
- 3) The SLDC will ensure that all thermal units with capacity 200 MW & above within the State are operated with free governor mode of operation.
- 4) The SLDC can ask for putting a generating station to demonstrate the declared availability by instructing the generating station to come up to the declared availability within time specified by generators.
- 5) The SLDC shall inform a SGS, in writing, if the continual monitoring demonstrates an apparent persistent or material mismatch between the despatch instructions and the Generating Unit output or breach of the Connection Conditions. Continued discrepancies shall be resolved by the State Grid Code Review Committee with a view to either improve performance in future, providing more realistic declarations or initiate appropriate action for any breach of Connectivity Conditions. Continued default by the generating stations entails penalty as may be determined by the Commission.



- 6) The SGS (excluding CPPs) shall provide to SLDC 15-minute block-wise generation summation outputs where no automatically transmitted metering or SCADA/RTU equipment exists.
- 7) CPPs shall provide to SLDC 15-minute block-wise export / import (MW and MVar).
- 8) The SGS shall provide any other logged readings that SLDC may reasonably require, for monitoring purposes where SCADA data is not available.

### **13.2 Monitoring of Drawal**

- 1) The SLDC shall continuously monitor actual MW drawal by Distribution Licensees and open access customers against their schedules through use of SCADA equipment wherever available, or otherwise using available metering. SLDC shall request ERLDC to provide any additional data required to enable this monitoring to be carried out.
- 2) The SLDC shall continuously monitor the actual MVAR import / export, voltage management in the State Transmission System.

### **13.3 Generating Unit Trippings**

- 1) The SGS shall promptly inform SLDC of the tripping of a Generating Unit, with reasons, SLDC shall intimate RLDC about the trippings and their revival. SLDC shall keep a written log of all such trippings, including the reasons with a view to demonstrating the effect on system performance and identifying the need for remedial measures.
- 2) The SGS shall submit a more detailed monthly report of tripping of their Generating Units to SLDC.

### **13.4 Data requirement**

The SGS shall submit data to SLDC as listed in Appendix-E (E-5).

## **CHAPTER - 14: SCHEDULING AND DESPATCH**

### **14.1 Demarcation of Responsibilities:**

- 1) The SLDC shall have the total responsibility for;
  - (i) scheduling / despatching of the state generating stations (SGS) (including generation of its embedded licensees),
  - (ii) regulating the demand of its control area,
  - (iii) scheduling their drawal from the ISGS (within their share in the respective plant's expected capability),
  - (iv) permitting long term access, medium term and short term open access transaction for embedded generation / consumers, in accordance with the contracts, and
  - (v) regulating the net drawal of their control area from the regional grid..
- 2) The SLDC, STU and Users shall always endeavour to restrict their net drawal from the grid to within their respective drawal schedules, whenever the system frequency is below 49.5 Hz. When the frequency falls below 49.0 Hz, requisite load shedding shall be carried out to curtail the over-drawal.
- 3) The SLDC, STU and the Distribution Licensees shall regularly carry out the necessary exercises regarding short-term and long-term demand estimation for the State, to enable them to plan in advance as to how they would meet their consumers' load without overdrawing from the grid.

- 4) The SGS, other generating stations and sellers shall be responsible for power generation/ power injection according to the daily schedules advised to them by the SLDC on the basis of the requisitions received from the beneficiaries.
- 5) While the SGS would normally be expected to generate power according to the daily schedules advised to them, it would not be mandatory to follow the schedules tightly. The SGS may deviate from the given schedules depending on the plant and system conditions. In particular, they would be allowed/encouraged to generate beyond the given schedule under deficit conditions.  
 Provided that when the frequency is higher than 50.2 Hz, the actual net injection shall not exceed the scheduled dispatch for that time and when the frequency is above 50.2 Hz, the SGS may (at their discretion) back down without waiting for an advice from SLDC to restrict the frequency rise. When the frequency falls below 49.7 Hz, the generation at all SGS (except those on peaking duty) shall be maximized, at least upto the level which can be sustained, without waiting for an advice from SLDC.
- 6) Deviations from the ex-power plant generation schedules shall, however, be appropriately priced through the UI mechanism as and when intra-State ABT is introduced by the Commission. Notwithstanding the above, the SLDC may direct the beneficiaries / SGS to increase/decrease their drawal/generation in case of contingencies e.g. overloading of lines/transformers, abnormal voltages, threat to system security. Such directions shall immediately be acted upon. In case the situation does not call for very urgent action and SLDC has some time for analysis, it shall be checked whether the situation has arisen due to deviations from schedules or due to any power flows pursuant to short-term open access. These shall be got terminated first, in the above sequence, before an action which would affect the scheduled supplies from SGS to the long-term customers is initiated.
- 7) It shall be incumbent upon the SGS to declare the plant capabilities faithfully, i.e., according to their best assessment. In case, it is suspected that they have deliberately over/under declared the plant capability contemplating to deviate from the schedules given on the basis of their capability declarations (and thus make money either as undue capacity charge or as the charge for deviations from schedule), the SLDC may ask the SGS to explain the situation with necessary backup data.
- 8) The STU shall install special energy meters on all inter-connections between the State constituents and other identified points for recording of actual net MWh interchanges and MVarh drawals. All concerned entities (in whose premises the special energy meters are installed) shall fully co-operate with the STU/SLDC and extend the necessary assistance by taking weekly meter readings and transmitting them to the SLDC.
- 9) The SLDC shall be responsible for computation of actual net injection of each SGS and actual net drawal of each beneficiary, 15 minute-wise, based on the above meter readings and for preparation of the State Energy Accounts. All computations carried out by SLDC shall be open to all constituents for checking/verifications for a period of 15 days. In case any mistake/omission is detected, the SLDC shall forthwith make a complete check and rectify the same.
- 10) The SLDC shall periodically review the actual deviation from the dispatch and net drawal schedules being issued, to check whether any of the constituents are indulging in unfair

gaming or collusion. In case any such practice is detected, the matter shall be reported to the State Grid Code Review Committee for further investigation/action.

#### **14.2 Scheduling and Despatch Procedure**

- 1) All State generating stations (SGS) and inter-State generating stations (ISGS), in whose output, more than one beneficiary has an allocated/contracted share, shall be duly listed by the SLDC. The station capacities and allocated/contracted shares of different beneficiaries shall also be listed out.
- 2) Each State shall be entitled to a MW dispatch upto (foreseen ex-power plant MW capability for the day) x (State's share in the station's capacity) for all such stations. In case of hydro-electric stations, there would also be a limit on daily MWh dispatch equal to (MWh generation capacity for the day) x (State's share in the station's capacity).
- 3) By 9 AM every day, each SGS shall intimate to the SLDC, the station-wise ex-power plant MW and MWh capabilities foreseen for the next day, i.e., from 0000 hrs to 2400 hrs of the following day, at 15 minutes interval.
- 4) By 9 AM everyday, the ISGS shall have to intimate the ERLDC, the station wise ex-power plant MW and MWh capability foreseen for the next day i.e from 0000 hrs to 2400 hrs of the following day and these foreseen capabilities of the ISGS and the corresponding MW and MWh entitlement of each state, shall be compiled by the ERLDC every day for next day, and advises all beneficiaries by 10 AM.
- 5) The above information of the foreseen capabilities of the SGS along with the entitlements of the State in various ISGS given by ERLDC and the corresponding MW and MWh entitlements of each beneficiary, shall be compiled by the SLDC every day for the next day, and advised to all beneficiaries by 11 AM. The beneficiaries shall review it vis-à-vis their foreseen load pattern and intimate to the SLDC by 1 PM their drawal schedule for each of the SGS/ISGS in which they have shares, long-term and/medium term bilateral interchanges, approved short-term bilateral interchanges.

Provided that a beneficiary's entitlements for plant-wise drawal/bilateral exchanges through the inter-State connections can be determined in lumpsum by the SLDC if it is operationally convenient and feasible to do.

- 6) The beneficiaries may also give standing instructions to the SLDC such that the SLDC itself may decide the drawal schedules for the beneficiaries
- 7) After considering the dispatch schedule and net drawal schedule for the State as intimated by ERLDC, by 6 PM each day, the SLDC shall convey;
  - (i) The ex-power plant "dispatch schedule" to each of the SGS, in MW for different hours, for the next day. The summation of the ex-power plant drawal schedules advised by all beneficiaries shall constitute the ex-power plant station-wise dispatch schedule for SGS.
  - (ii) The "net drawal schedule" to each beneficiary, in MW for different hours, for the next day. The summation of the station wise ex-power plant drawal schedules for all SGS/ISGS and drawal from State Grid consequent to bilateral interchanges, after deducting the transmission losses (estimated), shall constitute the beneficiary-wise drawal schedule.

- 8) The beneficiaries / SGS may inform any modifications/changes to be made in station-wise drawal schedule & bilateral interchanges /foreseen capabilities, if any, to SLDC by 9 PM or preferably earlier.
- 9) Upon receipt of such information, the SLDC after consulting the concerned Constituents shall issue the final 'drawal schedule' to each beneficiary and the final 'dispatch schedule' to each SGS by 11.00 PM.
- 10) The Hydro electric generation stations are expected to respond to grid frequency changes and inflow fluctuation. They would, therefore, be free to deviate from the given schedule as long as they do not indulge in gaming and do not cause a grid constraint. As a result, the actual net energy supply by a hydro generating station over a day may differ from schedule energy (ex-bus) for that day.
- 11) The declaration of the generating capability by hydro SGS should include limitation on generation during specific time periods, if any, on account of restriction(s) on water use due to irrigation, drinking water, industrial, environmental considerations etc. the SLDC shall periodically check that the generating station is declaring the capacity and energy sincerely.
- 12) Since variation of generation in run-of-river power stations shall lead to spillage, these shall be treated as must run stations. All renewable energy power plants except for biomass power plants with installed capacity of 10 MW and above, and non-fossil fuel based cogeneration plants shall be treated as 'MUST RUN' power plants and shall not be subjected to merit order dispatch principles.
- 13) Run-of-river power station with pondage and storage type power stations are designed to operate during peak hours to meet system peak demand. Maximum capacity of the station declared for the day shall be equal to the installed capacity including overload capability, if any, minus auxiliary consumption, corrected for the reservoir level. The SLDC shall ensure that generation schedule of such type of stations are prepared and the stations dispatched for optimum utilization of available hydro energy except in the event of specific system requirements/constraints.
- 14) The schedule finalized by the SLDC for hydro generating station, shall normally be such that the scheduled energy for a day equals the total energy (ex-bus) expected to be available on that day, as declared by the generating station, based on foreseen/planned water availability/release. It is also expected that the total net energy actually supplied by the generating station on that day would equal that declared total energy, in order that the water release requirement is met.
- 15) While finalizing the above daily dispatch schedules for the SGS, the SLDC shall ensure that the same are operationally reasonable, particularly in terms of ramping-up/ramping-down rates and the ratio between minimum and maximum generation levels.
- 16) While finalizing the drawal and dispatch schedules as above, the SLDC shall also check that the resulting power flows do not give rise to any transmission constraints. In case any constraints are foreseen, the SLDC shall moderate the schedules to the required extent, under intimation to the concerned Constituents. Any changes in the scheduled quantum of power which are too fast or involve unacceptably large steps may be converted into suitable ramps by the SLDC.

- 17) In case of forced outage of a unit, the SLDC shall revise the schedules on the basis of revised declared capability.
- 18) In the event of bottleneck in evacuation of power due to any constraint, outage, failure or limitation in the transmission system, associated switchyard and sub-stations owned by the State Transmission Utility or any other transmission licensee involved in intra-state transmission necessitating reduction in generation, the SLDC shall revise the schedules. The scheduled generation of the SGS shall be deemed to have been revised to be equal to actual generation and the scheduled drawals of the beneficiaries shall be deemed to have been revised to be equal to their actual drawals
- 19) In case of any grid disturbance, scheduled generation of all the SGS and scheduled drawal of all the beneficiaries shall be deemed to have been revised to be equal to their actual generation/drawal for all the time blocks affected by the grid disturbance. Certification of grid disturbance and its duration shall be done by the SLDC.
- 20) To discourage frivolous revisions, SLDC may, at its sole discretion, refuse to accept schedule/capability changes of less than two (2) percent of the previous schedule/capability.
- 21) After the operating day is over at 2400 hours, the schedule finally implemented during the day (taking into account all before-the-fact changes in dispatch schedule of generating stations and drawal schedule of the beneficiaries) shall be issued by SLDC. These schedules shall be the datum for commercial accounting.
- 22) The SLDC shall properly document all above information i.e. station-wise foreseen ex-power plant capabilities advised by the generating stations, the drawal schedules advised by beneficiaries, all schedules issued by the SLDC and all revisions/updating of the above.
- 23) The procedure for scheduling and the final schedules issued by SLDC shall be open to all constituents for any checking/verification, for a period of 5 days. In case any mistake/omission is detected, the SLDC shall forthwith make a complete check and rectify the same.
- 24) **Special dispensation for scheduling of wind and solar generation**  
Scheduling of wind and solar power generation plants would have to be done where the sum of generation capacity of such plants connected at the connection point to the transmission or distribution system is greater than 10 MW and connection point is 33 KV and above, where PPA has not yet been signed. For capacity and voltage level below this, it could be mutually decided between the wind Generator and the transmission or distribution utility, as the case may be.

## **CHAPTER - 15: METERING**

### **15.1 Applicability**

These Metering regulations shall be applicable to meters installed and to be installed by:

- 1) STU/Transmission Licensees,
- 2) Generating Stations connected to State Transmission System,
- 3) Distribution Licensees connected to State Transmission System,

- 4) EHV Consumers of Distribution Licensee(s) directly connected to State Transmission System,
- 5) Open Access Users availing Open Access on State Transmission system, and
- 6) Captive Generators connected to State Transmission System

#### 15.2 Type of meters

- 1) All interface meters, User meters, energy accounting and audit meters shall be of static type.
- 2) The meters not complying with these regulations shall be replaced by the STU or licensee on his own or on request of the User.

#### 15.3 Standards:

All interface meters, energy accounting meters and energy audit meters shall -

- (a) comply with the relevant standards of Bureau of Indian Standards (BIS). If BIS Standards are not available for a particular equipment or material, the relevant British Standards (BS), International Electro-technical Commission (IEC) Standards, or any other equivalent Standard shall be followed:

Provided that whenever an international Standard or IEC Standard is followed, necessary corrections or modifications shall be made for nominal system frequency, nominal system voltage and other conditions prevailing in India / State of Sikkim before actual adoption of the said Standard;

- (b) conform to the standards on 'Installation and Operation of Meters' as specified in Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006 and as amended from time to time.

#### 15.4 Ownership of meters

##### 1) Interface meters

- a) All interface meters installed at the points of interconnection with Inter-State Transmission System (ISTS) for the purpose of electricity accounting and billing shall be owned by CTU.
- b) All interface meters installed at the points of interconnection with State Transmission System excluding the system covered under sub-clause (a) above for the purpose of electricity accounting and billing shall be owned by STU.
- c) All interface meters installed at the points of inter connection between the two licensees excluding those covered under sub-clauses (a) and (b) above for the purpose of electricity accounting and billing shall be owned by respective licensee of each end.
- d) All interface meters installed at the points of inter connection for the purpose of electricity accounting and billing not covered under sub-clauses (a), (b) and (c) above shall be owned by supplier of electricity.

##### 2) Energy accounting and audit meters

Energy accounting and audit meters shall be owned by the generating company or STU, as the case may be.

#### 15.5 Location of meters

- 1) The location of interface meters, energy accounting and audit meters shall be as per the Table given below:

**Table**

| <b>Sl. No.</b>   | <b>Stages</b>             | <b>Main meter</b>        | <b>Check meter</b>       | <b>Standby meter</b>  |
|--|---------------------------|--------------------------|--------------------------|---|
| <b>A.</b>  | <b>Generating Station</b> | On all outgoing feeders. | On all outgoing feeders. | i) High Voltage (HV) side of Generator Transformers<br>ii) High Voltage (HV) side of all Station Auxiliary Transformers |
| (Explanation: The location of main, check and standby meters installed at the existing generating stations shall not be changed unless permitted by the concerned Authority) |                           |                          |                          |   |

|           |   |  |   |  |
|-----------|---|--|---|--|
| <b>B.</b> | <b>Transmission and Distribution System</b> | At one end of the line between the sub-stations of the same licensee, and at both ends of the line between sub-stations of two different licensees. Meters at both ends shall be considered as main meters for respective licensees. | - | There shall be no separate standby meter. Meter installed at other end of the line in case of two different licensees shall work as standby meter. |
| <b>C.</b> | <b>Inter-Connecting Transformer (ICT)</b>   | High Voltage (HV) side of ICT.   | - | Low Voltage (LV) side of ICT.  |

- 2) The generating companies or licensees may install meters at additional locations in their systems depending upon the requirement.

**3) Interface Meters**

- i) Users who have interconnection with the Inter-State Transmission System or State Transmission System and have been permitted open access by the Commission shall be provided with interface meters.
- ii) Users connected to distribution system and have been permitted open access by the Commission shall be provided with interface meters if they have to be covered under ABT.

**4) Energy Accounting and Audit Meters**

Energy accounting and audit meters shall be installed at such locations so as to facilitate accounting for the energy generated, transmitted, distributed in the various segments of the power system and the energy loss. The location of these meters shall be as under:

**i) Generating Stations**

- 1) at the stator terminal of the generator;
- 2) on HV and LV sides of the station and the unit auxiliary transformers;
- 3) on feeders to various auxiliaries.

**ii) Transmission System**

All incoming and outgoing feeders (If the interface meters do not exist).

**iii) Distribution System**

- 1) all incoming feeders (11 kV and above);
- 2) all outgoing feeders (11 kV and above);

**15.6 Accuracy Class of meters**

Every meter shall meet the requirement of accuracy class as specified in the standards given in the Central Electricity Authority "Installation and Operation of Meters" Regulations, 2006.

**15.7 Installation of meters**

- 1) Generating company or STU, as the case may be, shall examine, test and regulate all meters before installation and only correct meters shall be installed.
- 2) The meter shall be installed at locations, which are easily accessible for installation, testing, commissioning, reading, recording and maintenance.
- 3) In case Current Transformers (CTs) and Voltage Transformers (VTs) form part of the meters, the meter shall be installed as near the instrument transformers as possible to reduce the potential drop in the secondary leads.

**15.8 Operation, Testing and Maintenance of meters**

The operation, testing and maintenance of the meters shall be carried out by the generating company or the licensee, as the case may be.

**15.9 Access to meter**

The owner of the premises where, the meter is installed shall provide access to the authorized representative(s) of the Licensee for installation, testing, commissioning, reading and recording and maintenance of meters.

**15.10 Sealing of meters**

**1) Sealing Arrangements**

- a) All meters shall be sealed by the manufacturer at its works. In addition to the seal provided by the manufacturer at its works, the sealing of all meters shall be done as follows at various sealing points
  - (i) Sealing of interface meters, shall also be done by both the supplier and the buyer.
  - (ii) Sealing of User meters shall be done by the licensee.
  - (iii) Sealing of energy accounting and audit meters shall be done by the licensee or generating company as the case may be.
- b) Seal shall be unique for each utility and name or logo of the utility shall be clearly visible on the seals.
- c) Only the patented seals (seal from the manufacturer who has official right to manufacture the seal) shall be used.
- d) Polycarbonate or acrylic seals or plastic seals or holographic seals or any other superior seal shall be used.
- e) Lead seals shall not be used in the new meters. Old lead seals shall be replaced by new seals in a phased manner and the time frame of the same shall be submitted by the licensee to the Commission for approval.

**2) Removal of seals from meters**

**a) Interface meters**

Whenever seals of the interface meters have to be removed for any reason, advance notice shall be given to other party for witnessing the removal of seals and resealing of



the interface meter. The breaking and re-sealing of the meters shall be recorded by the party, who carries out the work, in the meter register, mentioning the date of removal and resealing, serial numbers of the broken and new seals and the reason for removal of seals.

**b) Energy accounting and audit meters**

Seal of the energy accounting and audit meter shall be removed only by the generating company or the STU who owns the meter

**15.11 Safety of meters**

- 1) The user in whose premises the interface meters are installed shall be responsible for their safety.
- 2) The User shall, as far as circumstances permit, take precautions for the safety of the meter installed in his premises belonging to the licensees.

**15.12 Meter reading and recording**

**1) Interface meters**

It shall be the responsibility of the Transmission Utility or Distribution licensee to take down the meter reading and record the metered data, maintain database of all the information associated with the interface meters and verify the correctness of metered data and furnish the same to various agencies.

**2) Energy accounting and audit meters**

It shall be the responsibility of the generating company or licensee to record the metered data, maintain database of all the information associated with the energy accounting and audit meters and verify the correctness of metered data. Each generating company or licensee shall prepare quarterly, half-yearly and yearly energy account for its system for taking appropriate action for efficient operation and system development.

**15.13 Meter failure or discrepancies**

**1) Interface meters**

- a) Whenever the difference between the readings of the Main meter and the Check meter for any month is more than 0.5%, the following steps shall be taken:
  - i) Checking of CT and VT connections;
  - ii) Testing of accuracy of interface meter at site with reference standard meter of accuracy class higher than the meter under test.

If the difference exists even after such checking or testing, then the defective meter shall be replaced with a correct meter.

- b) In case of conspicuous failures like burning of meter and erratic display of metered parameters and when the error found in testing of meter is beyond the permissible limit of error provided in the relevant standard, the meter shall be immediately replaced with a correct meter.
- c) In case where both the Main meter and Check meter fail, at least one of the meters shall be immediately replaced by a correct meter.
- d) Billing for the failure period:
  - i) The SLDC / STU shall develop a procedure for assessment of consumption of defective meter during the failure period of the meter and submit the same

to the Commission for its approval. The billing for the failure period of the meter shall be done as per the approved procedure.

- ii) Readings recorded by Main, Check and Standby meters for every time slot shall be analyzed, crosschecked and validated by the SLDC. The discrepancies, if any, noticed in the readings shall be informed by SLDC in writing to the energy accounting agency for proper accounting of energy. SLDC shall also intimate the discrepancies to the State Transmission Utility or the User, who shall take further necessary action regarding testing, calibration or replacement of the faulty meters in accordance with the provisions laid down.
- e) The defective meter shall be immediately tested and calibrated.

**2) Energy accounting and audit meters**

Energy accounting and audit meters shall be rectified or replaced by the generating company or licensee immediately after notice of any of the following abnormalities:

- a) the errors in the meter readings are beyond the limits prescribed for the specified Accuracy Class;
- b) meter readings are not in accordance with the normal pattern of the load demand;
- c) meter tampering, or erratic display or damage.

**15.14 Anti-tampering features of meters**

The meters shall be provided with such anti-tampering features as per the Standards on Installation and Operation of Meters given in the Schedule annexed to Central Electricity Authority (Installation and Operation of Meters) Regulations, 2006

**15.15 Quality assurance of meters**

- 1) The licensee shall set up appropriate number of accredited meter testing units or utilize the services of other accredited testing laboratories. The licensee shall take immediate action to get the accreditations of their existing meter testing units from NABL, if not already done.
- 2) The generating company or licensee shall ensure that all type, routine and acceptance tests are carried out by the manufacturer complying with the requirement of the relevant BIS or BS or IEC as the case may be.

**15.16 Calibration and periodical testing of meters**

**1) Interface meter**

- a) At the time of commissioning, each interface meter shall be tested by the licensee at site for accuracy using standard reference meter of better accuracy class than the meter under test.
- b) All interface meters shall be tested at least once in five years. These meters shall also be tested whenever the energy and other quantities recorded by the meter are abnormal or inconsistent with electrically adjacent meters. Whenever there is unreasonable difference between the quantity recorded by interface meter and the corresponding value monitored at the billing center via communication network, the communication system and terminal equipment shall be tested and rectified. The meters may be tested using NABL accredited mobile laboratory or at any accredited laboratory and recalibrated if required at manufacturer's works.

- c) Testing and calibration of interface meters may be carried out in the presence of the representatives of the licensee and beneficiary by giving due notice of testing in advance.

**2) Energy accounting and audit meters**

Energy accounting and audit meters shall be tested at site at least once in five years or whenever the accuracy is doubtful or whenever the readings are inconsistent with the readings of other meters, e.g., check meters, standby meters. The testing must be carried out without removing the CTs and VTs connection. Testing may be carried out through NABL accredited mobile laboratory using secondary injection kit, measuring unit and phantom loading or at any accredited test laboratory and recalibrated if required at manufacturer's works.

**15.17 Standards on Installation and Operation of Meters**

**Part I: Standards Common To All Type of Meters**

- (1) These standards provide for specification of meters, immunity to external factors, sealing points and functional requirements that are required from regulatory perspective. Detailed technical specification shall be prepared by the purchaser of the meter.

**(2) Specifications of meters**

|                                   |  |
|-----------------------------------|--|
| <b>Standard Reference Voltage</b> | As per IS  |
| <b>Voltage Range</b>              | As per IS  |
| <b>Standard Frequency</b>         | As per IS  |
| <b>Standard Basic Current</b>     | As per IS<br>(Current range of consumer meters shall be so chosen as to record the load current corresponding to the sanctioned load)  |
| <b>Accuracy Class</b>             | Meters shall meet the following requirements of Accuracy Class:  |
|                                   | <b>Interface meters</b> 0.2S   |
|                                   | <b>Consumer meters</b>   |
|                                   | Up to 650 volts 1.0 or better  |
|                                   | Above 650 volts and up to 33 kilo volts 0.5S or better   |
|                                   | Above 33 kilo volts 0.2S   |
|                                   | <b>Energy accounting and audit meters</b><br>The accuracy class of meters in generation and transmission system shall not be inferior to that of 0.2S Accuracy Class. The accuracy class of meters in distribution system shall not be inferior to that of 0.5S Accuracy Class |

|  |           |
|--|-----------|
| <b>Starting Current and Maximum Current</b>                | As per IS |
| <b>Power Factor Range</b>                                  | As per IS |
| <b>Power Frequency Withstand Voltage</b>                   | As per IS |
| <b>Impulse Voltage Withstand Test for 1.2/50 micro sec</b> | As per IS |
| <b>Power Consumption</b>                                   | As per IS |

- (3) Meter shall have downloading facilities of metered data through Meter Reading Instrument (MRI).

**(4) Immunity to External Factors**

The meter shall be immune to external influences like magnetic induction, vibration, electrostatic discharge, switching transients, surge voltages, oblique suspension and harmonics and necessary tests shall be carried out in accordance with relevant standard.

**(5) Sealing Points**

Sealing shall be done at the following points (as applicable):

- (a) Meter body or cover
  - (b) Meter terminal cover
  - (c) Meter test terminal block
  - (d) Meter cabinet
- (6) The accuracy class of Current transformers (CTs) and Voltage transformers (VTs) shall not be inferior to that of associated meters. The existing CTs and VTs not complying with these regulations shall be replaced by new CTs and VTs, if found defective, non-functional or as per the directions of the Appropriate Commission. In case the CTs and VTs of the same Accuracy Class as that of meters can not be accommodated in the metering cubicle or panel due to space constraints, the CTs and VTs of the next lower Accuracy Class can be installed.
- (7) The Voltage Transformers shall be electromagnetic VT or Capacitive Voltage Transformer (CVT).

**Part II: Standards for interface meters**

**(1) Functional Requirements:**

- (a) The Interface meters suitable for ABT shall be static type, composite meters as self-contained devices for measurement of active and reactive energy, and certain other parameters as described in the following paragraphs. The meters shall be suitable for being connected directly to voltage transformers (VTs) having

a rated secondary line-to-line voltage of 110 V, and to current transformers (CTs) having a rated secondary current of 1A (Model-A :3 element 4 wire or Model C: 2 element , 3 wire) or 5A (model-B: 3 element , 4 wire or Model D: 2 element 3 wire). The reference frequency shall be 50Hz.

- (b) The meters shall have a non-volatile memory in which the following shall be automatically stored:
  - i) Average frequency for each successive 15-minute block, as a two digit code (00 to 99 for frequency from 49.0 to 51.0Hz).
  - ii) Net Wh transmittal during each successive 15-minute block, upto second decimal, with plus/minus sign.
  - iii) Cumulative Wh transmittal at each midnight, in six digits including one decimal.
  - iv) Cumulative VARh transmittal for voltage high condition, at each midnight, in six digits including one decimal.
  - v) Cumulative VARh transmittal for voltage low condition, at each midnight, in six digits including one decimal.
  - vi) Date and time blocks of failure of VT supply on any phase, as a star(\*) mark.
- (c) The meters shall store all the above listed data in their memories for a period of at least ten days. The data older than ten days shall get erased automatically. Each meter shall have an optical port on its front for tapping all data stored in its memory using a hand held data collection device. The meter shall be suitable for transmitting the data to remote location using appropriate communication medium.
- (d) The active energy (Wh) measurement shall be carried out on 3-phase, 4-wire principle, with an accuracy as per class 0.2 S of IEC-687/IEC-62053-22. In model-A and C, the energy shall be computed directly in CT and VT secondary quantities, and indicated in watt-hours. In model-B and Model D , the energy display and recording shall be one fifth of the Wh computed in CT and VT secondary quantities.
- (e) The Var and reactive energy measurement shall also be on 3-phase, 4-wire principle, with an accuracy as per class 2 of IEC-62053-23 or better. In model-A or Model C, the Var and VARh computation shall be directly in CT and VT secondary quantities. In model-B or Model D, the above quantities shall be displayed and recorded as one-fifth of those computed in CT and VT secondary quantities. There shall be two reactive energy registers, one for the period when average RMS voltage is above 103% and the other for the period the voltage is below 97%.
- (f) The 15-minute Wh shall have a +ve sign when there is a net Wh export from substation busbars, and a -ve sign when there is a net Wh import. The integrating (cumulative) registers for Wh and Varh shall move forward when there is Wh/Varh export from substation busbars, and backward when there is an import.
- (g) The meters shall also display (on demand), by turn, the following parameters :
  - (i) Unique identification number of the meter
  - (ii) Date
  - (iii) Time
  - (iv) Cumulative Wh register reading
  - (v) Average frequency of the previous 15-minute block
  - (vi) Net Wh transmittal in the previous 15-minute block, with +/-sign

- (vii) Average percentage voltage
  - (viii) Reactive power with +/- sign
  - (ix) Voltage-high VARh register reading
  - (x) Voltage-low VARh register reading.
- (h) The three line-to-neutral voltages shall be continuously monitored, and in case any of these falls below 70%, the condition shall be suitably indicated and recorded. The meters shall operate with the power drawn from the VT secondary circuits, without the need for any auxiliary power supply. Each meter shall have a built-in calendar and clock, having an accuracy of 30 seconds per month or better.
  - (i) The meters shall be totally sealed and tamper-proof, with no possibility of any adjustment at site, except for a restricted clock correction. The harmonics shall be filtered out while measuring Wh, Var and VARh, and only fundamental frequency quantities shall be measured/computed.
  - (j) The Main meter and the Check meter shall be connected to same core of CTs and VTs.

### **Part III: Standards for energy accounting and audit meters**

1. The energy accounting and audit meters shall be suitable for measurement, recording and display of cumulative active energy with date and time.
2. The energy accounting and audit meters may also have the facility to measure, record and display one or more of the following parameters depending upon the energy accounting and audit requirement. All parameters excluding instantaneous electrical parameters shall also be stored in memory.
  - (a) Apparent power
  - (b) Phase wise kilowatt at peak KVA
  - (c) Phase wise KVA(reactive) at peak KVA
  - (d) Phase wise voltage at peak KVA
  - (e) Power down time
  - (f) Average power factor
  - (g) Line currents
  - (h) Phase voltages
  - (i) Date and time
  - (j) Tamper events
3. The energy accounting and audit meter shall have data storage capacity for at least 35 days in a non-volatile memory.
4. Energy accounting and audit meters shall have facility to download the parameters through meter reading instruments as well as remote transmission of data over communication network.

#### **15.18 Data requirements**

State Generating Station (SGS) and State Transmission Utility (STU) shall provide data to each other and SLDC as specified in Appendix-G.

## **CHAPTER - 16: INTER-USER BOUNDARY SAFETY**

### **16.1 Objective**

The objective of this chapter is to achieve an agreement and consistency on the principles of safety when working across the inter-user boundary (cross boundary) between one User and another User.

### **16.2 Designated Persons**

The STU and all Users shall nominate and notify authorized persons to be responsible for the co-ordination of safety across their boundary. These persons shall be referred to as Designated Persons.

### **16.3 Procedure to work on Inter User Boundary Circuits**

- 1) The STU shall issue a list of Designated Persons names, designations and telephone numbers to all Users who have a direct inter-user boundary with him. This list shall be updated promptly, whenever there is a change of name, designation or telephone number of any designated persons named in the list.
- 2) All Users with a direct inter-user boundary with STU shall issue a similar list of their Designated Persons to STU. This list shall be updated promptly whenever there is any change of name etc in the list.
- 3) Whenever any work across an inter-user boundary is to be carried out by the User or the STU, the Designated Persons of the User or STU as the case may be, wishing for Line Clear Permit (Permit to Work (PTW)) shall personally contact the other relevant Designated Person. If the Permit to Work cannot be obtained personally, the Designated Persons shall contact through telephone and exchange code word or secrete code to ensure correct identification of both agencies.
- 4) If the work extends one shift, the Designated Person shall ensure that the Relieving Designated Person is fully briefed on the nature of the work and the code words in operation.
- 5) The Designated Person (s) shall co-operate to establish and maintain the precautions necessary for the required work to be carried out in a safe manner. Both the established isolation and the established earth shall be kept in locked position with "Men Working" tag, where such facilities exist, and shall be clearly identified.
- 6) Work shall not commence until the Designated Person incharge of the work of the User is satisfied that all the safety precautions have been established. This Designated Person shall issue approved safety documentation and work permit (PTW) to the working party to allow work to commence.

The Permit to Work in respect of EHV lines and other interconnections shall be issued with the consent of SLDC.

- 7) When work is completed and safety precautions are no longer required, the Designated Person who has been responsible for the work being carried out shall make direct contact with the other Designated Person to return the Permit to Work and removal of those safety precautions.

Return of Permit to Work in respect of specified EHV lines and interconnections shall be informed to SLDC.

- 8) The equipment shall only be considered as suitable for connecting back to service when all safety measures are confirmed as removed, by direct communication using code word contact between the two Designated Persons, and after ensuring that the return of Permit to Work from the working party has taken place.
- 9) STU shall develop an agreed written procedure for Inter-User Boundary safety and continuously update it.
- 10) Any dispute concerning inter-user boundary safety shall be resolved at the level of STU, if STU is not a party. In case STU is a party, the dispute shall be referred to the Grid Code Review Committee for resolving the dispute.

#### **16.4 Special consideration**

- 1) For inter-user boundary between STU and other User's circuits, all Users shall comply with the approved safety rules, which must be in accordance with IE Rules.
- 2) Each Designated Person shall maintain a legibly written safety log, in chronological order, of all operations and messages relating to safety co-ordination sent and received by him. All safety logs shall be retained for a period of not less than 10 years.

### **CHAPTER - 17: SAFETY AND LINE CLEAR PERMITS**

#### **17.1 Safety Standards:**

- 1) The STU shall prepare their own "Safety Manual" for the maintenance of Transmission Lines, and Substations and got vetted by an accredited agency. Copies of this safety manual shall be provided at all the sub-stations, concerned departments of STU and Users. For the guidance of the Shift Operators, "Operation and Maintenance Manuals" for each Sub-station shall be prepared by the STU and Users containing all the maintenance and operation schedules based on the recommendations of the manufacturers of the various equipments installed in the Substation. These manuals shall be periodically reviewed based on the experience gained and replacement of equipments. A maintenance register for all the equipments including the station batteries shall be maintained at the respective Substations. These shall be updated as and when the maintenance work is carried out and shall be periodically reviewed by the Commission. Similar registers shall be maintained for the Transmission and Sub-Transmission Lines.
- 2) The 'Operation and Maintenance Manual' shall clearly specify the details of isolation and earthing to be provided for allowing work on the equipments. The 'Single Line Diagram' of the Substation indicating the positions of various isolating devices shall be prominently displayed in the station. Charts showing the clearances from live parts (section clearance) for working on the isolated equipments where workmen are allowed to work shall be displayed prominently at each Substation.



- 3) The STU and Users shall affix the "Danger" boards (of a design as per relevant ISS No. 2551) prominently displayed at a conspicuous place at all the locations as required in the IE Rules.
- 4) All the equipment including the system batteries in the receiving stations and Substations shall be maintained in good condition as per the manufacturers' manuals and also as per relevant Indian and / or International standards. The DC system (Batteries etc) provided in all these stations shall be properly maintained with no appreciable leakage current. On-line monitoring system for monitoring of leakage and detection of ground faults shall be adopted.

## **17.2 Line Clear Permit (LCP):**

Approved formats shall be used while issuing and returning line clear permit.

Model Formats for Requisition of line clear permit, Issue for line clear Permit and Line clear Return permit are appended.

The Format - I designated as "Requisition for Line Clear Permit" shall be used by the requesting Safety Coordinator who is an authorized person. The Format - 2 designated as "Line Clear Permit" shall be used at the time of issue of Line Clear Permit.

The Format -3 designated as "Line Clear Return" shall be used for the Permit return of the Line Clear Permit after the work is completed for which the Line Clear Permit is taken.

## FORMAT – 1

Serial No. ....

### REQUISITION FOR LINE CLEAR PERMIT

Date .....

Time .....

I Sri/Srimati \_\_\_\_\_ request Line Clear Permit on the following EHT / HT Line/  
Equipment.

EHT / HT Apparatus/Line Identification:

Details of works to be carried out:

Estimated time required for completion:

Name and Signature .....

.....

(Person Requesting Line Clear Permit)

Designation.....

Date.....

---

(FOR USE IN SUBSTATION FROM WHERE LINE CLEAR PERMIT WILL BE ISSUED)

(a) Line Clear Permit issued : Yes/No

(b) Number and Date of Issue:

(c) Time of Issue:

(d) Date & Time of Return:

(e) Remarks: See Check List LCP – Format-2

---

RECEIPT OF Line clear Per No,.....

Date.....

I have received confirmation from .....(Name of Issuing Safety Coordinator) at  
.....(location) that the safety precautions have been established and the  
instructions will not be issued at his location for their removal until his LCP is cancelled.

Name and Signature.....

(Person Requesting Line Clear Permit)

## FORMAT – 2

Serial No. ....

### LINE CLEAR PERMIT

LCP Number.....

Dated.....Time.....

#### **CHECK LIST OF THE LINE CLEAR PERMIT:**

- (a) Name of location for which line clear is issued.
- (b) Reference and Authority requisitioning line clear: (Indicate serial number of LCP requisition).
- (c) Identity of HV Apparatus.
- (d) Sources from which the Line/Equipment is charged.
- (e) No./name of Circuit Breaker/Isolating Switch open at each of above sources.
- (f) Whether confirmed that the Line is disconnected at both ends.
- (g) Whether line is Earthed at both ends.
- (h) Whether the Circuit Breaker truck removed in case of indoor switchgear controlling the Feeder/ Equipment for which line clear is given.
- (i) Whether Isolating Switches controlling the feeder/equipment for which line clear is given are locked and kept in safe custody.
- (j) Time of issue of Line Clear Permit and LCP No.
- (k) Name of requesting Safety Coordinator on whom LCP is issued.
- (l) Approximate Time for returning LCP as ascertained from the Requesting Coordinator.

Name and Signature.....

Designation.....

#### **LINE CLEAR PERMIT**

LCP No.....

I Sri/Srimati \_\_\_\_\_ (Issuing Safety Coordinator) do hereby issue permission to Sri/ Srimati \_\_\_\_\_ (Requesting Safety Coordinator) for carrying out works as per requisition No.....date.....Time .....

The EHT/ HT Line/equipment herein described is declared safe.

The permission is subject to the conditions given on backside of this Permit.

Name and Signature.....

(Person issuing Line Clear Permit)

Designation.....

(To be printed on the reverse of LCP:Format-2)

## CONDITIONS:

- (a) This permit is valid only for working on the Feeder/Equipment mentioned herein and not in any other Feeder/Equipment.
- (b) Only authorized persons are allowed to work on Feeder / Equipment for which the permit has been issued.
- (c) Works as per requisition only should be carried out.
- (d) Before touching any part of the Feeder / Equipment it should be ensured that earthing at two points on either side through standard discharge rods connected with good Earths. Temporary Earths may be removed after completion of all works and after all the men have come down from the Feeder/Equipment.
- (e) Work should be so planned that the Line Clear is returned before or at the time indicated. If unavoidable delay is anticipated advance information should be given to the location from where the Line Clear is issued.
- (f) Before return of the Line Clear, it should be ensured that all the men, materials, tools/ tackles etc. on line have returned and reported that all temporary earths are removed. There should also be a check on the material, Tools and Plant issued for the work to ensure that nothing is left behind on the Line or Equipment.
- (g) Only authorized persons should return Line Clear.
- (h) In case the Line Clear cannot be returned in person, the same may be returned to the Line Clear Issuing Authority over Telephone by naming the Code Words assigned and the telephone number which is used for naming the Code Words assigned. In case two or more different Code Words are issued to the two or more persons in whose favour the permit is given, those persons must jointly return the Line Clear by naming their own Code Words. The Line Clear Return will not be accepted unless returned by all these persons.
- (i) The Line Clear issuing authority should go through the checklist of Line Clear Return before accepting it.
- (j) If Line Clear is returned over telephone, the Line Clear Return Form duly filled and signed should be sent to the Line Clear Issuing Authority by post immediately for record.
- (k) Control persons should keep all the required data of LCP issued & LCR received. He should monitor and keep specific note in log sheet when more than one LCP are issued on same line/ equipment / bay along with code words.

**LINE CLEAR PERMIT RETURN**

LCP Number.....

Date .....Time.....

I Sri/Srimati\_\_\_\_\_ hereby return the LCP no \_\_\_\_\_ at \_\_\_\_\_ issued for the following HT/EHT Line/Apparatus.

I declare that all the crew who were sent on work have been withdrawn, temporary earth(s) removed, all repair tools and materials checked and the Feeders/Equipments mentioned below are safe to be energised.

(a) EHT / HT Apparatus/Line Identification:

(b) Details of work done

**CHECK LIST TO BE TICKED OFF:**

- (a) Whether all men withdrawn: Yes ☐
- (b) Whether all temporary Earthing removed: Yes ☐
- (c) Whether all materials, Tools and Plant used in the work have been checked: Yes ☐
- (d) Code Number (If used when Line Clear is returned over phone)\_\_\_\_\_

Name and Signature.....

(Person Returning Line Clear Permit)

Designation.....

## **CHAPTER - 18: DATA REGISTRATION**

### **18.1 Responsibility**

- 1) All Users are responsible for submitting the required up-to-date data to STU/ SLDC in accordance with the provisions of the State Grid Code.
- 2) All Users shall provide STU and SLDC, the names, addresses and telephone numbers of the persons responsible for sending the data.
- 3) Responsibility for the correctness of the data rests with the concerned User providing the data.
- 4) The STU shall inform all Users and SLDC, the names, addresses, and telephone numbers of the persons responsible for receiving data.
- 5) The STU shall provide up-to-date data to Users as provided in the relevant Chapters of this State Grid Code.

### **18.2 Data to be registered**

The data required to be registered/exchanged has been listed in the Appendices under various categories. The data so far applicable to the particular User need only to be registered and exchanged with STU or SLDC.

### **18.3 Changes in User's data**

Whenever any User becomes aware of a change to any items of data that is registered with STU, the User must promptly notify the STU of the changes. STU on receipt of intimation of the changes shall promptly correct the database accordingly. This shall also apply to any data compiled by STU regarding its own system.

### **18.4 Method of submitting data**

- 1) The data shall be furnished in the standard formats for data submission and such formats must be used for the written submission of data to SLDC and STU. Where standard formats are not enclosed they would be developed by SLDC or STU in consultation with Users.
- 2) All data to be submitted under the Schedule(s) must be submitted to SLDC / STU or to such other department and/or entity as STU may from time to time notify to Users. The name of the person who is submitting each schedule of data shall be indicated.
- 3) Where a computer data link exists between a User and SLDC/ STU, data may be submitted via this link. The data shall be in the same format as specified for paper transmission. The User shall specify the method to be used in consultation with the SLDC/ STU and resolve issues such as protocols, transmission speeds etc. at the time of transmission.

**18.5 Data not supplied**

All Users are obliged to supply data as referred to in the individual Chapters of this State Grid Code and listed out in this Data Registration Chapter Appendices. In case any data is not supplied by any User or is not available, STU or SLDC may, acting reasonably, if and when necessary, estimate such data depending upon the urgency of the situation. Similarly, in case any data is not supplied by STU, the concerned User may, acting reasonably, if and when necessary, estimate such data depending upon urgency of the situation. Such estimates will in each case, be based upon corresponding data for similar Plant or Apparatus or upon such other information, the User or STU or SLDC, as the case may be, deems appropriate.

**18.6 Special considerations**

The SLDC and any other User may at any time make reasonable request to STU for extra data as necessary. STU shall supply data, required/requested.

**CHAPTER - 19: MISCELLANEOUS**

**19.1 Dispute redressal:**

Any dispute regarding interpretation of any provision of the State Grid Code, shall be addressed to Secretary to the Commission. The decision of the Commission shall be taken as final and binding on all concerned.

**19.2 Power to remove difficulties:**

If any difficulty arises in giving effect to any of the provisions of the State Grid Code, the Commission may, by general or specific order, make such provisions not inconsistent with the provisions of the Act, as may appear to be necessary for removing the difficulty.

**19.3 Power to relaxation**

The Commission may by general or special order, for reasons to be recorded in writing and after giving an opportunity of hearing to the parties likely to be effected by grant of relaxation, may relax any of the provisions of the State Grid Code on its own motion or on an application made before it by an interested person.

**19.4 Power to amend**

The Commission may, at any time, vary, alter, modify or amend any provision of State Grid Code.

**19.5 General**

Nothing in these regulations shall bar the Commission to deal with any matter or exercise any power under the Act, for which no regulations have been framed, and the Commission may deal such matters, powers and functions in a manner it thinks fit.

**By Order of the Commission**

**Sd/-  
Secretary / SSERC**

## **APPENDIX A : STANDARD PLANNING DATA**

(Reference to: Chapter 4 para 4.3 (9), para 4.6 (a,b,c) and Chapter 5, para 5.1 (4 [d]), para 5.11

### **A-1 STANDARD PLANNING DATA (GENERATION)**

#### **A.1.1 THERMAL POWER STATIONS (COAL / GAS/FUEL LINKED)For**

##### **State Generating Stations (SGS)**

#### **(1) GENERAL**

|     |   |   |
|-----|---|---|
| i   | Site  | Furnish location map to scale showing roads, railway lines, Transmission lines, canals, pondage and reservoirs if any.              |
| ii  | Coal linkage/ Fuel (Like Liquefied Natural Gas, Naphtha etc.) linkage | Give information on means of coal transport / carriage. In case of other fuels, give details of source of fuel and their transport. |
| iii | Water Sources   | Give information on availability of water for operation of the Power Station.   |
| iv  | Environmental   | State whether forest or other land areas are affected.  |
| v   | Site Map (To Scale)   | Showing area required for Power Station coal linkage, coal yard, water pipe lines, ash disposal area, colony etc.                   |
| vi  | Approximate period of construction                                    |   |

#### **(2) CONNECTION**

|    |                                     |   |
|----|-------------------------------------|---|
| i  | Point of Connection                 | Furnish single line diagram of the proposed Connection with the system. |
| ii | Step up voltage for Connection (kV) |   |

#### **(3) STATION CAPACITY**

|    |  |   |
|----|--|---|
| i  | Total Generating Station capacity (MW) | State whether development will be carried out in phases and if so, furnish details. |
| ii | No. of units & unit size (MW)          |   |



#### (4) GENERATING UNIT DATA

|     |                       |  |
|-----|-----------------------|--|
| i   | Steam Generating Unit | State type, capacity, steam pressure, stream temperature etc.  |
| ii  | Steam turbine         | State type, capacity.<br>Type<br>Rating (MW)<br>Speed (RPM)<br>Terminal voltage (KV)<br>Rated Power Factor<br>Reactive Power Capability<br>(MVA) in the range 0.95 of leading and 0.85 lagging   |
| iii | Generator             | Short Circuit Ratio<br>Direct axis (saturated) transient reactance (% on MVA rating)<br>Direct axis (saturated) sub-transient reactance ( % on MVA rating) Auxiliary Power Requirement MW and MVA Capability curve Ramp-up and ramp-down rate Generator Characteristic curve<br>Make<br>Phases<br>Type |
| iv  | Generator Transformer | Rated capacity (MVA)<br>Voltage Ratio (HV/LV)<br>Tap change Range (+ % to - %)<br>Percentage Impedance (Positive Sequence at Full load)  |

#### A.1.2 HYDRO POWER STATIONS (For SGS)

##### (1) GENERAL

|      |   |  |
|------|---|--|
| i    | Site  | Give location map to scale showing roads, railway lines, and transmission lines.                     |
| ii   | Site map (To scale)   | Showing proposed canal, reservoir area, water conductor system, fore-bay, power house etc.           |
| iii  | Submerged Area  | Give information on area submerged, villages submerged, submerged forest land, agricultural land etc |
| iv   | Whether storage type or run of river type                                   |  |
| v    | Whether catchment receiving discharges from other reservoir or power plant. |  |
| vi   | Full reservoir level  |  |
| vii  | Minimum draw down level.  |  |
| viii | Tail race level   |  |
| ix   | Design Head   |  |
| x    | Reservoir level v/s energy potential curve                                  |  |
| xi   | Restraint, if any, in water discharges                                      |  |
| xii  | Approximate period of construction.   |  |

**(2) CONNECTION**

|    |                                     |  |
|----|-------------------------------------|--|
| i  | Point of Connection                 | Give single line diagram proposed Connection with the Transmission System. |
| ii | Step up voltage for Connection (KV) |  |

**(3) STATION CAPACITY**

|    |                                   |   |
|----|-----------------------------------|---|
| i  | Total Power Station capacity (MW) | State whether development is carried out in phases and if so furnish details. |
| ii | No. of units & unit size (MW)     |   |

**(4) GENERATING UNIT DATA**

|     |                            |   |
|-----|----------------------------|---|
| i   | Operating Head (in Metres) | a. Maximum<br>b. Minimum<br>c. Average  |
|     | Hydro Unit                 | Capability to operate as synchronous condenser.<br>Water head versus discharges curve (at full and part load)<br>Power requirement or water discharge while operating as synchronous condenser  |
| ii  | Turbine                    | State Type and capacity   |
| iii | Generator                  | Type Rating (MVA)/ Speed (RPM) Terminal voltage (KV)/ Rated Power Factor/ Reactive Power Capability (MVA) in the range 0.95 of leading and 0.85 of lagging/ MW & MVA capability curve of generating unit/ Short Circuit Ratio/ Direct axis transient (saturated) reactance (% on rated MVA)/ Direct axis sub-transient (saturated) reactance (% on rated MVA)<br>Auxiliary Power Requirement (MW) |
| iv  | Generator- Transformer     | a. Type<br>b. Make<br>c. Phasesd.<br>d. Rated Capacity (MVA)<br>e. Voltage Ratio HV/LV<br>f. Tap change Range (+% to -%)<br>g. Percentage Impedance (Positive Sequence at Full Load).   |

## **A.2 . STANDARD PLANNING DATA (TRANSMISSION)**

### **For STU and Transmission Licensees**

STU shall make arrangements for getting the required data from different Departments of STU/other transmission licensees (if any) to update its Standard Planning Data in the format given below:

|       |   |
|-------|---|
| i.    | Name of line (Indicating Power Stations and substations connected).   |
| ii.   | Voltage of line (KV).   |
| iii.  | No. of circuits.  |
| iv.   | Route length (Km).  |
| v.    | Conductor sizes.  |
| vi.   | Line parameters (PU values).<br>(a) Resistance/Km<br>(b) Inductance/Km<br>(c) Susceptance / Km  |
| vii.  | Approximate power flow expected- MW & MVar.   |
| viii. | Terrain of the route- Give information regarding nature of terrain i.e. forest land, fallow land, agricultural and river basin, hill slope etc. |
| ix.   | Route map (to scale) - Furnish topographical map showing the route showing existing power lines and telecommunication lines.                    |
| x.    | Purpose of Connection- Reference to Scheme, wheeling to other States etc.   |
| xi.   | Approximate period of Construction.   |

## **A.3. . STANDARD PLANNING DATA (DISTRIBUTION)**

### **For Distribution licensees**

#### **(1) GENERAL**

|     |  |  |
|-----|--|--|
| i   | Area Map (to scale)  | Furnish map of Manipur/Mizoram duly marked with the area of supply relevant for the Distribution License . |
| ii  | Consumer Data  | Furnish categories of consumers, their numbers and connected loads.  |
| iii | Reference to Electrical Divisions presently in charge of the Distribution. |  |

**(2) CONNECTION**

|     |  |  |
|-----|--|--|
| i   | Points of Connection                                       | Furnish single line diagram showing points of Connection |
| ii. | Voltage of supply at points of Connection                  |  |
| iii | Names of Grid Sub-Station feeding the points of Connection |  |

**(3) LINES AND SUBSTATIONS**

|    |                  |   |
|----|------------------|---|
| i  | Line Data        | Furnish lengths of line and voltages within the Area.               |
| ii | Sub-station Data | Furnish details of 132/33 KV sub-stations, 33/11 KV sub-station etc |

**(4) LOADS**

|     |   |  |
|-----|---|--|
| i   | Loads drawn at points of Connection.  |  |
| ii  | Details of loads fed at EHV, if any. Give name of consumer, voltage of supply, contract demand/load and name of Grid Sub-station from which line is drawn, length of EHV line from Grid Sub-station to consumer's premises. |  |
| iii | Reactive Power compensation installed   |  |

**(5) DEMAND DATA (FOR ALL LOADS 1 MW AND ABOVE)**

|      |   |  |
|------|---|--|
| i    | Type of load  | State whether furnace loads, rolling mills, traction loads, other industrial loads, pumping loads etc. |
| ii   | Rated voltage and phase                                 |  |
| iii  | Electrical loading of equipment                         | State number and size of motors, types of drive and control arrangements.                              |
| iv   | Sensitivity of load to voltage and frequency of supply. |  |
| v    | Maximum Harmonic content of load.                       |  |
| vi   | Average and maximum phase unbalance of load.            |  |
| vii  | Nearest sub-station from which load is to be fed.       |  |
| viii | Location map to scale                                   | Showing location of load with reference to lines and sub-stations in the vicinity.                     |

## **(6) LOAD FORECAST DATA**

|     |  |
|-----|--|
| i   | Peak load and energy forecast for each category of loads for each of the succeeding 5 years.   |
| ii  | Details of methodology and assumptions on which forecasts are based.   |
| iii | Details of loads 1 MW and above.<br>Name of prospective consumer.<br>Location and nature of load.<br>Sub-Station from which to be fed.<br>Voltage of supply.<br>Phasing of load. |

## **APPENDIX B : DETAILED PLANNING DATA**

(Reference to: Chapter 4, para 4.3 (7), para 4.6 (a,b,c) and Chapter 5 para 5.11)

### **B.1 DETAILED PLANNING DATA (GENERATION)**

#### **B.1.1 THERMAL POWER STATIONS (COAL / GAS / FUEL LINKED) (For SGS)**

##### **(1) GENERAL**

- i. Name of Power Station.
- ii. Number and capacity of Generating Units (MW).
- iii. Ratings of all major equipments (Boilers and major accessories, Turbines, Alternators, Generator Unit Transformers etc).
- iv. Single line Diagram of Power Station and switchyard.
- v. Relaying and metering diagram.
- vi. Neutral Grounding of Generating Units.
- vii. Excitation control- (What type is used?) e.g. Thyristor, Fast Brushless Excitors)
- viii. Earthing arrangements with earth resistance values.
- ix. Start up engine (for gas stations)
- x. Turbine details (for gas stations)

##### **(2) PROTECTION AND METERING**

- i. Full description including settings for all relays and protection systems installed on the Generating Unit, Generator unit Transformer, Auxiliary Transformer and electrical motor of major equipments etc.
- ii. Full description including settings for all relays installed on all outgoing feeders from Power Station switchyard, Tie circuit breakers, and incoming circuit breakers.

- iii. Full description of inter-tripping of circuit breakers at the point or points of Connection with the Transmission System.
- iv. Most probable fault clearance time for electrical faults on the User's System.
- v. Full description of operational and commercial metering schemes.

**(3) SWITCHYARD**

- i. In relation to interconnecting transformers:

- 1. Rated MVA.
- 2. Voltage Ratio.
- 3. Vector Group.
- 4. Positive sequence reactance for maximum, minimum, normal Tap. (% on MVA).
- 5. Positive sequence resistance for maximum, minimum, normal Tap. (% on MVA).
- 6. Zero sequence reactance (% on MVA).
- 7. Tap changer Range (+% to -%) and steps.
- 8. Type of Tap changer. (off/on load).

- ii. In relation to switchgear including circuit breakers, isolators on all circuits connected to the points of Connection:

- 1. Rated voltage (KV).
- 2. Type of circuit breaker (MOCB/ABCB/SF6).
- 3. Rated short circuit breaking current (KA) 3 phase.
- 4. Rated short circuit breaking current (KA) 1 phase.
- 5. Rated short circuit making current (KA) 3 phase.
- 6. Rated short circuit making current (KA) 1-phase.
- 7. Provisions of auto re-closing with details.

- iii. In relation to the Lightning Arresters -

Technical data

- iv. In relation to the Communication –

Details of communication equipment installed at points of connections.

- v. In relation to the Basic Insulation Level (KV) -

- 1. Bus bar.
- 2. Switchgear.
- 3. Transformer bushings.
- 4. Transformer windings.

**(4) PARAMETERS OF GENERATING UNITS**

- i. Rated terminal voltage (KV).
- ii. Rated MVA.
- iii. Rated MW.
- iv. Speed (rpm) or number of poles.
- v. Inertia constant H (MW Sec./MVA).
- vi. Short circuit ratio.
- vii. Direct axis synchronous reactance (% on MVA)  $X_d$ .
- viii. Direct axis (saturated) transient reactance (% on MVA)  $X_d'$ .
- ix. Direct axis (saturated) sub-transient reactance (% on MVA)  $X_d''$ .
- x. Quadrature axis synchronous reactance (% on MVA)  $X_q$ .
- xi. Quadrature axis (saturated) transient reactance (% on MVA)  $X_q'$ .
- xii. Quadrature axis (saturated) sub-transient reactance (% on MVA)  $X_q''$ .
- xiii. Direct axis transient open circuit time constant (Sec)  $T'do$ .
- xiv. Direct axis sub-transient open circuit time constant (Sec)  $T''do$ .
- xv. Quadrature axis transient open circuit time constant (Sec)  $T'qo$ .
- xvi. Quadrature axis sub-transient open circuit time constant (Sec)  $T''qo$ .
- xvii. Stator Resistance (ohm)  $R_a$ .
- xviii. Neutral grounding details.
- xix. Stator leakage reactance (ohm)  $X_1$ .
- xx. Stator time constant (Sec).
- xxi. Rated Field current (A).
- xxii. Open Circuit saturation characteristic for various terminal Voltages giving the compounding current to achieve the same.
- xxiii. MW and MVA Capability curve

**(5) PARAMETERS OF EXCITATION CONTROL SYSTEM:**

- i. Type of Excitation.
- ii. Maximum Field Voltage.
- iii. Minimum Field Voltage.
- iv. Rated Field Voltage.

- v. Details of excitation loop in block diagrams showing transfer functions of individual elements using I.E.E.E. symbols.
- vi. Dynamic characteristics of over - excitation limiter.
- vii. Dynamic characteristics of under-excitation limiter.

**(6) PARAMETERS OF GOVERNOR:**

- i. Governor average gain (MW/Hz).
- ii. Speeder motor setting range.
- iii. Time constant of steam or fuel Governor valve.
- iv. Governor valve opening limits.
- v. Governor valve rate limits.
- vi. Time constant of Turbine.
- vii. Governor block diagram showing transfer functions of individual elements using I.E.E.E. symbols.

**(7) OPERATIONAL PARAMETERS:**

Minimum notice required to synchronize a Generating Unit from de- synchronization.

- i. Minimum time between synchronizing different Generating Units in a Power Station.
- ii. The minimum block load requirements on synchronizing.
- iii. Time required for synchronizing a Generating Unit for the following conditions:
  - 1. Hot
  - 2. Warm
  - 3. Cold
- iv. Maximum Generating Unit loading rates for the following conditions:
  - 1. Hot
  - 2. Warm
  - 3. Cold
- v. Minimum load without oil support (MW).

**(8) GENERAL STATUS**

- i. Detailed Project report.
- ii. Status Report
  - 1. Land
  - 2. Coal
  - 3. Water
  - 4. Environmental clearance
  - 5. Rehabilitation of displaced persons
- iii. Techno-economic approval by Central Electricity Authority (CEA).
- iv. Approval of State Government/Government of India.
- v. Financial Tie-up.

**(9) CONNECTION**

- i. Reports of Studies for parallel operation with the State Transmission System.
- ii. Short Circuit studies
- iii. Stability Studies.
- iv. Load Flow Studies.



- v. Proposed Connection with the State Transmission System.
  - a. Voltage
  - b. No. of circuits
  - c. Point of Connection.

### **B.1.2 HYDRO - ELECTRIC STATIONS (For SGS)**

#### **(1) GENERAL**

- i. Name of Power Station.
- ii. No and capacity of units. (MVA)
- iii. Ratings of all major equipment.
  - a. Turbines (HP)
  - b. Generators (MVA)
  - c. Generator Transformers (MVA)
  - d. Auxilliary Transformers (MVA)
- iv. Single line diagram of Power Station and switchyard.
- v. Relaying and metering diagram.
- vi. Neutral grounding of Generator.
- vii. Excitation control.
- viii. Earthing arrangements with earth resistance values.
- ix. Reservoir Data.
  - a. Salient features
  - b. Type of Reservoir
  - c. Multipurpose
  - d. For Power
  - e. Operating Table with
    - 1. Area capacity curves and
    - 2. Unit capability at different net heads

#### **(2) PROTECTION**

- i. Full description including settings for all relays and protection systems installed on the Generating Unit, Generator transformer, auxiliary transformer and electrical motor of major equipment included etc.
- ii. Full description including settings for all relays installed on all outgoing feeders from Power Station switchyard, tiebreakers, and incoming breakers.
- iii. Full description of inter-tripping of breakers at the point or points of Connection with the Transmission System.
- iv. Most Probable fault clearance time for electrical faults on the User's System.

#### **(3) SWITCHYARD**

- i. Interconnecting transformers:
  - 1. Rated MVA
  - 2. Voltage Ratio
  - 3. Vector Group
  - 4. Positive sequence reactance for maximum, minimum and normal Tap.(% on MVA).

5. Positive sequence resistance for maximum, minimum and normal Tap.(% on MVA).
  6. Zero sequence reactance (% on MVA)
  7. Tap changer range (+% to -%) and steps.
  8. Type of Tap changer (off/on load).
  9. Neutral grounding details.
- ii. Switchgear (including circuit breakers, Isolators on all circuits connected to the points of Connection).
1. Rated voltage (KV).
  2. Type of Breaker (MOCB/ABCB/SF6).
  3. Rated short circuit breaking current (KA) 3 phase.
  4. Rated short circuit breaking current (KA) 1 phase.
  5. Rated short circuit making current (KA) 3 phase.
  6. Rated short circuit making current (KA) 1 phase.
  7. Provisions of auto re-closing with details.
- iii. Lightning Arresters  
Technical data
- iv. Communications  
Details of Communications equipment installed at points of connections.
- v. Basic Insulation Level (KV)
1. Bus bar.
  2. Switchgear.
  3. Transformer Bushings
  4. Transformer windings.

#### **(4) GENERATING UNITS**

- i. Parameters of Generator
1. Rated terminal voltage (KV).
  2. Rated MVA.
  3. Rated MW
  4. Speed (rpm) or number of poles.
  5. Inertia constant H (MW sec./MVA).
  6. Short circuit ratio.
  7. Direct axis synchronous reactance  $X_d$  (% on MVA).
  8. Direct axis (saturated) transient reactance (% on MVA)  $X'_d$ .
  9. Direct axis (saturated) sub-transient reactance (% on MVA)  $X''_d$ .
  10. Quadrature axis synchronous reactance (% on MVA)  $X_q$ .
  11. Quadrature axis (saturated) transient reactance (% on MVA)  $X'_q$ .
  12. Quadrature axis (saturated) sub-transient reactance (% on MVA)  $X''_q$ .
  13. Direct axis transient open circuit time constant (sec)  $T'_{do}$ .
  14. Direct axis sub-transient open circuit time constant (sec)  $T''_{do}$ .
  15. Quadrature axis transient open circuit time content (sec)  $T'_{qo}$ .
  16. Quadrature axis transient open circuit time constant (sec)  $T''_{qo}$ .
  17. Stator Resistance (ohm)  $R_a$ .
  18. Stator leakage reactance (ohm)  $X_l$ .
  19. Stator time constant (sec).
  20. Rated Field current (A).

21. Neutral grounding details.
  22. Open Circuit saturation characteristics of the Generator for various terminal voltages giving the compounding current to achieve this.
  23. Type of Turbine.
  24. Operating Head (metres)
  25. Discharge with full gate opening (cumecs)
  26. Speed Rise on total Load throw off(%).
  27. MW and MVA<sub>r</sub> Capability curve
- ii. Parameters of excitation control system:
  - iii. Parameters of governor:
  - iv. Operational parameter:
    1. Minimum notice required to Synchronize a Generating Unit from de-synchronization.
    2. Minimum time between Synchronizing different Generating Units in a Power Station.
    3. Minimum block load requirements on Synchronizing.

**(5) GENERAL STATUS**

- i. Detailed Project Report.
- ii. Status Report.
  1. Topographical survey
  2. Geological survey
  3. Land
  4. Environmental Clearance
  5. Rehabilitation of displaced persons.
- iii. Techno-economic approval by Central Electricity Authority.
- iv. Approval of State Government/Government of India.
- v. Financial Tie-up.

**(6) CONNECTION**

- i. Reports of Studies for parallel operation with the State Transmission System.
  1. Short Circuit studies
  2. Stability Studies.
  3. Load Flow Studies.
- ii. Proposed Connection with the State Transmission System.
  1. Voltage
  2. No. of circuits
  3. Point of Connection.

**(7) RESERVOIR DATA**

- i. Dead Capacity
- ii. Live Capacity

**B.2 DETAILED SYSTEM PLANNING DATA – TRANSMISSION**  
**For STU and Transmission Licensees**

**(1) GENERAL**

- i. Single line diagram of the Transmission System down to 66KV,33KV bus at Grid Sub-station detailing:
  1. Name of Sub-station.
  2. Power Station connected.
  3. Number and length of circuits.
  4. Interconnecting transformers.
  5. Sub-station bus layouts.
  6. Power transformers.
  7. Reactive compensation equipment.
- ii. Sub-station layout diagrams showing:
  1. Bus bar layouts.
  2. Electrical circuits, lines, cables, transformers, switchgear etc.
  3. Phasing arrangements.
  4. Earthing arrangements.
  5. Switching facilities and interlocking arrangements.
  6. Operating voltages.
  7. Numbering and nomenclature:
  8. Transformers.
  9. Circuits.
  10. Circuit breakers.
  11. Isolating switches.

**(2) LINE PARAMETERS (for all circuits)**

- i. Designation of Line.
  1. Length of line (Km).
  2. Number of circuits Per Circuit values.
  3. Operating voltage (KV).
  4. Positive Phase sequence reactance (pu on 100 MVA) X1
  5. Positive Phase sequence resistance (pu on 100 MVA) R1
  6. Positive Phase sequence susceptance (pu on 100 MVA) B1
  7. Zero Phase sequence reactance (pu on 100 MVA) X0
  8. Zero Phase sequence resistance (pu on 100 MVA) R0
  9. Zero Phase sequence susceptance (pu on 100 MVA) B0

**(3) TRANSFORMER PARAMETERS (For all transformers)**

- i. Rated MVA
- ii. Voltage Ratio
- iii. Vector Group
- iv. Positive sequence reactance, maximum, minimum and normal (pu on 100 MVA) X1
- v. Positive sequence resistance, maximum, minimum and normal (pu on 100 MVA) R1
- vi. Zero sequence reactance (pu on 100 MVA).
- vii. Tap change range (+% to -%) and steps.
- viii. Details of Tap changer. (Off/On load).

**(4) EQUIPMENT DETAILS (For all substations)**

- i. Circuit Breakers
- ii. Isolating switches
- iii. Current Transformers
- iv. Potential Transformers /CVTs

**(5) RELAYING AND METERING**

- i. Protection relays installed for all transformers and feeders along with their settings and level of co-ordination with other Users.
- ii. Metering Details.

**(6) SYSTEM STUDIES**

- i. Load Flow studies (Peak and lean load for maximum hydro and maximum thermal generation).
- ii. Transient stability studies for three-phase fault in critical lines.
- iii. Dynamic Stability Studies
- iv. Short circuit studies (three-phase and single phase to earth)
- v. Transmission and Distribution Losses in the Transmission System.

**(7) DEMAND DATA (For all substations)**

Demand Profile (Peak and lean load) for next 5 years.

**(8) REACTIVE COMPENSATION EQUIPMENT**

- i. Type of equipment (fixed or variable).
- ii. Capacities and/or Inductive rating or its operating range in MVar.
- iii. Details of control.
- iv. Point of Connection to the System.

**B.3 DETAILED PLANNING DATA (DISTRIBUTION)**

**For Distribution Licensees**

**(1) GENERAL**

- i. Distribution map (To scale). Showing all lines up to 11KV and sub-stations belonging to the Supplier.
- ii. Single line diagram of Distribution System (showing distribution lines from points of Connection with the Transmission System, 132/33 KV sub stations, 33/11KV 110/22-11 KV substations, and consumer bus in case of consumers fed directly from the Transmission System).
- iii. Numbering and nomenclature of lines and sub-stations (Identified with feeding Grid sub-stations of the Transmission and concerned 220/132/33/11KV, 132/33/11KV, and 33/11KV 110/22-11 KV sub-stations of Licensee).

**(2) CONNECTION**

- i. Points of Connection (Furnish details of existing arrangement of Connection).
- ii. Details of metering at points of Connection.

**(3) LOADS**

- i. Details of major loads of 1 MW and above to be contracted for next 5 years.
- ii. Demand profile of Distribution System (Current & forecast)

### **APPENDIX C : SITE RESPONSIBILITY SCHEDULE**

(Reference to: Chapter 5 para 5.5 (2))

Name of Power Station / Sub – Station:

Site Owner:

Site Manager:

Tel. Number:

Fax Number:

| <b>Item of Plant / Apparatus</b> | <b>Plant Owner</b> | <b>Safety responsibility</b> | <b>Control responsibility</b> | <b>Operation responsibility</b> | <b>Maintenance responsibility</b> | <b>Remarks</b> |
|----------------------------------|--------------------|------------------------------|-------------------------------|---------------------------------|-----------------------------------|----------------|
| ___KV<br>Switch yard             |                    |                              |                               |                                 |                                   |                |
| All equipment including bus bars |                    |                              |                               |                                 |                                   |                |
| Feeders                          |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
| Generating units                 |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |
|                                  |                    |                              |                               |                                 |                                   |                |

**APPENDIX D : PROTECTION DATA**  
(Reference to: Chapter 6)

**PROTECTION:**

| <b>Item</b>  | <b>Due date/Time</b>                              |
|--|---|
| a) Generators/CPPs/IPP's shall submit details of protection requirement and schemes installed by them as referred to in B-1.<br><br>1. Detailed planning Data under sub-section "Protection and Metering"                          | As applicable to<br>Detailed Planning<br><br>Data |
| b) The STU shall submit details of protection equipment and schemes installed by them as referred to in B-2. Detailed system Data, Transmission under sub-section "Relaying and Metering" in relation to Connection with any User. | As applicable to Detailed<br>Planning Data        |

## **APPENDIX E : OPERATIONAL PLANNING DATA**

### **E.1 OUTAGE PLANNING DATA**

(Reference to - Chapter 11)

#### **1 Demand Estimates**

(For Distribution Licensees)

| <b>Item</b>   | <b>Due date/ Time</b>         |
|---|-------------------------------|
| a) Estimated aggregate month-wise annual sales of Energy in Million Units and peak and lean demand in MW & MVar at each Connection point for the next financial year. | 15th November of current year |
| b) Estimated aggregate day-wise monthly sales of Energy in million Units and peak and lean demand in MW & MVar at each Connection point for the next month.           | 25th of current month         |
| c) 15 Minute block-wise demand estimates for the day ahead.   | 09.00 Hours every day.        |

#### **(2) Estimates of Load Shedding for Distribution Licensee**

| <b>Item</b>   | <b>Due date / Time</b>           |
|---|----------------------------------|
| a) details of discrete load blocks that may be shed to comply with instructions issued by SLDC when required, from each connection point. | Sooner after connection is made. |

#### **(3) Year ahead outage programme (For the financial year)** **(i) Generator outage programme for (SGS)**

| <b>Item</b>   | <b>Due date / Time</b>              |
|---|-------------------------------------|
| a) Identification of Generating Unit.   | 15 <sup>th</sup> November each year |
| b) MW, Which will not be available as a result of Outage.   |                                     |
| c) Preferred start date and start-time or ranges of start dates and start times and period of outage.           |                                     |
| d) If outages are required to meet statutory requirement, then the latest – date by which outage must be taken. |                                     |



**(ii) Affecting Intra – State Transmission System**

| Item  | Due date /Time                     |
|---|------------------------------------|
| a) MW, which will not be available as a result of Outage from Imports through external connections. | 15 <sup>th</sup> November eachyear |
| b) Start date and start time and period of Outage.  |                                    |

**(iii) Year ahead CPP's outage programme (Affecting Intra – State Transmission System)**

| Item  | Due date /Time                      |
|---|-------------------------------------|
| a) MW, which will not be available as a result of Outage from Imports through external connections. | 15 <sup>th</sup> November each year |
| b) Start date and start time and period of Outage.  |                                     |

**(iv) Year ahead Distribution Licensees outage programme**

| Item  | Due date /Time                     |
|---|------------------------------------|
| a) Loads in MW not available from any connection point. Identification of connection point. | 15 <sup>th</sup> November eachyear |
| b) Period of suspension of drawal with start date and start time.                           |                                    |

**(v) STU's Overall outage programme**

| Item                                     | Due date / Time                     |
|--|-------------------------------------|
| a) Report on proposed outage programme   | 15 <sup>th</sup> February each year |
| b) Release of finally agreed outage plan |                                     |

**E-2. GENERATION SCHEDULING DATA**

(Reference to: Chapter 14)

**SCHEDULE AND DISPATCH (For SGS, IPPs and CPPs)**

| Item   | Due date/ Time   |
|--|------------------|
| <b>Day ahead 15 Minute block-wise MW/MVAr availability (00.00 - 24.00 Hours).</b>                | <b>09.00 hrs</b> |
| a) Status of Generating Unit Excitation AVR in service (Yes/No).                                 | 09.00 hrs        |
| b) Status of Generating Unit Speed Control System. Governor in service (Yes/No).                 | 09.00 hrs        |
| c) Spinning reserve capability (MW).   | 09.00 hrs        |
| d) Backing down capability with/without oil support (MW).  | 09.00 hrs        |
| <b>Hydro reservoir levels and restrictions.</b>  | <b>09.00 hrs</b> |
| a) Generating Units 15 Minute block-wise summation outputs (MW).                                 | 09.00 hrs        |
| b) Day ahead 15 Minute block-wise MW entitlements from Central Sector Generation Power Stations. | 09.00 hrs        |

**E-3 CAPABILITY DATA**

(Reference to: Chapter 10)

**For SGS**

| Item  |  |
|---|--|
| a) Generators and IPPs shall submit to STU up-to-date capability curves for all Generating Unit.                      | On receipt of request from STU / SLDC. |
| b) CPPs shall submit to STU net return capability that shall be available for export /import from Transmission System |  |

**E-4 RESPONSE TO FREQUENCY CHANGE**

(Reference to: Chapter 10)

**For SGS**

| Item  |  |
|---|--|
| a) Primary Response in MW at different levels of loads ranging from minimum generation to registered capacity for frequency changes resulting in fully opening of governor valve. | On receipt of request from STU / SLDC. |
| b) Secondary response in MW to frequency changes  |  |

**E-5 MONITORING OF GENERATION**

(Reference to: Chapter 9)

**For (SLDC)****MONITORING OF GENERATION AND DRAWAL (For SGS)**

| Item  |   |
|---|---|
| a) SGS shall provide 15-minute block-wise generation summation to SLDC. | Real time basis                           |
| b) CPPs shall provide 15-minute block-wise export / import MW to SLDC.  | Real time basis                           |
| c) Logged readings of Generators to SLDC.                               | As required                               |
| d) Detailed report of generating unit tripping on monthly basis.        | In the first week of the succeeding month |

**E-6 ESSENTIAL AND NON ESSENTIAL LOAD DATA**

(Reference to: Chapter 12)

**For SGS****CONTINGENCY PLANNING (For SLDC)**

| Item   | Due date/ Time                       |
|--|--------------------------------------|
| Schedule of essential and non-essential loads on each discrete load block for purposes of load shedding. | As soon as possible after connection |

**APPENDIX - F : INCIDENT REPORTING (OTHER THAN ACCIDENTS)**

(Reference to: Chapter 12 para 12.3)

First report

Date: \_\_\_\_\_

Time: \_\_\_\_\_

| S. No. | Item  | Details |
|--------|---|---------|
| 1      | Date and time of incident   |         |
| 2      | Location of incident  |         |
| 3      | Type of incident  |         |
| 4      | System parameters before the incident<br>(voltage, frequency, flows, generation etc.) |         |
| 5      | Relay indications received and performance of protection                              |         |
| 6      | Damage to equipment   |         |
| 7      | Supplies interrupted and duration, if applicable                                      |         |
| 8      | Amount of generation lost, if applicable  |         |
| 9      | Possibility of alternate supply arrangement   |         |
| 10     | Estimate of time to return to service   |         |
| 11     | Cause of incident   |         |
| 12     | Any other relevant information and remedial action taken                              |         |
| 13     | Recommendations for future improvement / repeat incident                              |         |
| 14     | Name of the organization  |         |

**APPENDIX – G : METERING DATA**  
(Reference to: Chapter 15)

**1 METERING**

| <b>Item</b>   | <b>Due date/ Time</b>                    |
|---|--|
| a) SGS shall submit details of metering equipment and schemes installed by them as referred in B-1. Detailed Planning Data under sub-section "Protection and Metering"  | As applicable to Detailed Planning Data  |
| b) STU s shall submit details of metering equipment and schemes installed by them as referred in B-2. Detailed System Data, Transmission under sub-section "Relaying and Metering" in relation to connection with any User. | As applicable to Detailed Planning Data. |

## ABBREVIATIONS

|       |  |
|-------|--|
| ABT   | Availability Based Tariff  |
| BIS   | Bureau of Indian Standards   |
| BS    | British Standards  |
| CEA   | Central Electricity Authority  |
| CERC  | Central Electricity Regulatory Commission                            |
| CPP   | Captive Power Plant  |
| CT    | Current Transformer  |
| CTU   | Central Transmission Utility   |
| DC    | Double Circuit   |
| EHT   | Extra High Tension   |
| ERPC  | Eastern Regional Power Committee                                     |
| HT    | High Tension   |
| ICT   | Inter Connecting Transformer   |
| IEC   | International Electro-Technical Commission Standards                 |
| IEGC  | Indian Electricity Grid Code   |
| IPP   | Independent Power Producer   |
| ISGS  | Inter-State Generating Station                                       |
| ISTS  | Inter State Transmission System                                      |
| KV    | Kilo Volt  |
| LCP   | Line Clear Permit  |
| NABL  | National Accreditation Board of Testing and Calibration Laboratories |
| PGCIL | Power Grid Corporation of India Ltd.                                 |
| PTW   | Permit to Work   |
| RLDC  | Regional Load Despatch Centre  |
| SCADA | Supervisory Central and Data Acquisition                             |
| SC    | Single Circuit   |
| SGC   | State Grid Code  |
| SGS   | State Generating Station   |
| SLDC  | State Load Despatch Centre   |
| STS   | State Transmission System  |
| STU   | State Transmission Utility   |
| UI    | Unscheduled Interchange  |
| VT    | Voltage Transformer  |